REV

SUPPORTS LEGEND:

ISSUED FOR REFERENCE

REMARKS FOR MECHANICAL SUBCONTRACTOR:

1) LINES 1.1/2" AND SMALLER SHALL BE SUPPORTED IN FIELD IF NOT OTHERWISE INDICATED.

DESCRIPTION


CROSSING BETWEEN WELDS ON PIPELINE SHALL NOT BE ADMITTED

2) ALL DIMENSION AND PROPER CONFIGURATION FOR LINES NPS 1.1/2" AND SMALLER SHALL BE CHECKED IN FIELD BEFORE CONSTRUCTION. 3) FOR THE COMPONENTS MARKED AS FIELD WELDED WITH THIS SYMBOL ★, ONE WELD FOR ADJUSTMENT OF IN LINE COMPONENT MUST BE LEFT

4) FOR EXTRA PIPE LENGTH REFER TO 4274-LZ-PC-00000603.
5) GUSSETING TO BE IMPLEMENTED BY MECHANICAL SUBCONTRACTOR AS PER 45-L-45-000-2-00-80004 / 4274-XH-SG-00000002

(7) IN CASE OF DISCREPANCIES BETWEEN DATA SHOWN ON ISO AND IN LINE LIST (AS APPLICABLE, DATA SHOWN IN LINE LIST GOVERN.

8) ACTUAL CUT LENGTH OF PIPE AND FIELD WELDS SHALL BE DEFINED BY MECHANICAL SUBCONTRACTOR (REF. TO 4274-LZ-PC-0000060)



A=RESTING SUPPORT G=GUIDE F=AXIAL STOP B=ANCHOR M=SPRING S=TEFLON PAD WHERE[A] WITHOUT NUMBERING IS INDICATED, THIS MEANS THAT THERE IS A REST DIRECTLY ON STEEL STRUCTURE.

P.VAZE

CHECK BY

G.PAGANON

APPR. BY

25-AUG-23

U.CHAVAN

TRESS CALC. No

PIPE LAYOUT No

APPR. CLIENT

19-A-19-000-1-01-00001 sheet 51

19-L-19-000-2-00-86197 sheet 3

19-L-19-000-2-00-80602

BILL OF MATERIAL HOLD COMPONENT DESCRIPTION ITEM CODE QTY (IN) STATUS PIPE - A106-B PE SMLS T01AC03Z02 S-XS < PIPA010A11/2XS > (L-6679) I132777 FITTINGS TEE ASME B16.11 3000# A105N SWE SWE - R11FNC441101 NREQD < TESA300LBK1/2> 1/2X1/2 I1651299 (L-179) 90 ELBOW ASME B16.11 3000# A105N SWE SWE - R31FNC441103 NREQD I1651295 <90FA300LBK1/2>(L-178) PLUG ROUND HEAD ASME B16.11 - A105N MTE NREQD - R42FQC44W001 NREQD 110088243 FLANGES SW FLANGE ASME B16.5 150# A105N RFFE SWE 125 - 250 AARH F02CDC44B105 S-XS I5378341 <SWFA300R151/2XS>(L-295) SASKETS SPIRAL WOUND GASKET ASME B16.20 150# RFTBE 304/GRAFOIL CARBON STEEL SS 304 1/2 163508894 ASME B16.5 G03GDP1IS12 < N/A> (N/A) STUD BOLTS&NUTS ASME B18.31.2/ B18.2.2 A193-B7/A194-2H INCH SIZE I010B0301 153437179 <SB2R51G1/221/2> - 2 NUTS PER BOLT - 60 mm Length 153437223 STUD BOLTS&NUTS ASME B18.31.2/ B18.2.2 A193-B7/A194-2H INCH SIZE I010B0301 <SB2R51G1/231/4> - 2 NUTS PER BOLT - 80 mm Length ALVES / IN-LINE ITEMS I10013685 BALL VALVE API 608 150# A216-WCB RFFE 316/R-PTFE, GF B7/2H 125 - 250 AARH 2PSB-FULL BORE FLOATING BALL OHW ASME B16.5 V04JDC29BZZG NREQD <N/A> (N/A) DISC CHECK WER VALVE ASME B16.34 150# A216-WCB RETBE 316/R-PTFE, GF 125 -I10016146 250 AARH SL VERTICAL&HORIZONTAL CRACK. PRESS. 1/2 PSI ASME B16.5 V40IDC29P01 NREOD <N/A> (N/A) BALL VALVE ASME B16.34 800# A105N SWE FTE 316/R-PTFE, GF 3PSB-RED BORE I67130076 FLOATING BALL OHW FIRE SAFE :API 607 & ANTISTATIC DEVICES "A60T series" TEAL V04JIC44126IG NREQD <N/A> (N/A) PIPE MATERIAL NOTES: 1. FOR TECHNICAL DETAILS SEE LINE LIST. 2. FOR VENT, DRAIN OR INSTRUMENT CONNECTION DETAILS SEE 45-L-45-000-2-00-80102 CS 3. WELDING ACCORDING TO 45-L-45-000-2-00-80021 HEAT TREATMENT (PWHT) 5. CODE SHOWN IN BOM BETWEEN "<" & ">" DENOTES REPSOL UNICODE. "<N/A>" MEANS UNICODE IS "NOT AVAILABLE" PAINTING SCHEME (3) CONTRACTOR: CONTRACTOR DRAWING NUMBER: PROJECT: 4001008 PIPING CLASS 4274-XH-DL-2121LPN40Z16-1 WELDING CLASS (4) LOW LINEAL DENSITY POLYETHILENE (PEL) CLIENT / COMPLEX AND POLYPROPYLENE (PP) PLANTS REPSOL POLYMEROS/ PED CATEGORY FOR PROJECT - ALBA PROJECT SINES INDUSTRIAL COMPLEX Art 4.3 REPSQL INSULATION CODE / THK. (mm) DRAWING NUMBER ANNEX

**ISSUED FOR** 

REFERENCE

FILENAME: 19-000-2-02-00001 sheet 2121LPN40Z16-1.dwg

19-000-2-02-00001 sheet 2121LPN40Z16-1

00