SUPPORTS LEGEND: DATE: REV.

REMARKS FOR MECHANICAL SUBCONTRACTOR:

1) LINES 1.1/2" AND SMALLER SHALL BE SUPPORTED IN FIELD IF NOT OTHERWISE INDICATED.

DESCRIPTION

□ DENOTES PARTS LIST NO PIPE SUPPORT —

6) CROSSING BETWEEN WELDS ON PIPELINE SHALL NOT BE ADMITTED.

ISSUED FOR CONSTRUCTION

ISSUED FOR CONSTRUCTION

2) ALL DIMENSION AND PROPER CONFIGURATION FOR LINES NPS 1.1/2" AND SMALLER SHALL BE CHECKED IN FIELD BEFORE CONSTRUCTION. 3) FOR THE COMPONENTS MARKED AS FIELD WELDED WITH THIS SYMBOL ★, ONE WELD FOR ADJUSTMENT OF IN LINE COMPONENT MUST BE LEFT

9) WHERE EARTHING BONDING IS REQUIRED, MECHANICAL SUBCONTRACTOR TO PERFORM IT BASED ON DOC. 45-P-000-7-06-00902/ 4274 -NN-DW-00000002 AND ASSEMBLY NO FEA005 AND FE019.

29-FEB-24

20-OCT-23

A=RESTING SUPPORT G=GUIDE F=AXIAL STOP B=ANCHOR M=SPRING S=TEFLON PAD WHERE A WITHOUT NUMBERING IS INDICATED, THIS MEANS THAT THERE IS A REST DIRECTLY ON STEEL STRUCTURE.

P.VAZE

P.VAZE

CHECK BY

G.PAGANONI

G.PAGANONI

APPR. BY

M.YADAV


M.YADAV

4) FOR EXTRA PIPE LENGTH REFER TO 4274-LZ-PC-00000603.
5) GUSSETING TO BE IMPLEMENTED BY MECHANICAL SUBCONTRACTOR AS PER 45-L-45-000-2-00-80004 / 4274-XH-SG-00000002.

() CROSSING BETWEEN WEEDS ON THE ELING STALE NOT BE ADMITTED.

7) IN CASE OF DISCREPANCIES BETWEEN DATA SHOWN ON ISO AND IN LINE LIST (AS APPLICABLE, DATA SHOWN IN LINE LIST GOVERN.

8) ACTUAL CUT LENGTH OF PIPE AND FIELD WELDS SHALL BE DEFINED BY MECHANICAL SUBCONTRACTOR (REF.TO 4274-LZ-PC-00000603'



NS HOLD COMPONENT DESCRIPTION ITEM CODE QTY (IN) STATUS PIPE - A312-TP304/304L DUAL GR BE SMLS T01AL2CV02 S-10S < PIPB04DB2210S > I3364302 11.4 M (L-PIP113) STRAIGHT TEE ASME B16.9 A403-WP304/304L DG BE SMLS C31DL2FV01 S-10S 12259149 <TEBB23DF314071407> (L-TEB28) REDUCING SOCKOLET MSS-SP-97 3000# A182-F304/304L DUAL GR BE SWE -2X1 1/2 12258341 R13DNL2AV101 NREQD < SOKB450LB01413 > (L-SOK04) ECCENTRIC SWAGE MSS SP-95 - A403-WP304/304L DG BE PE SMLS SCH1-10S SCH2-40S I2495783 R22FOL2FVZ10 <ESWB04DGR14071101> (L-ESW20) 90 LR ELBOW ASME B16.9 A403-WP304/304L DG BE SMLS C01DL2FV01 S-10S I2259133 <90LB23DF3210S> (L-8052) PIPE SUPPORTS SUPPORT HOR NOT INS.PIP.N4G1 VERTICAL STAKES WELDED TO STR. ST42 L80X80X10 U BOLT (FOR GUIDE)-P02D WELDED BRACKET TO STRUCT, SB01 L80X80X10 335 0 WELDED BRACKET TO STRUCT. SB01 L80X80X10 336 11 U BOLT (FOR GUIDE)-P02D 336 PIPE MATERIAL NOTES: 1. FOR TECHNICAL DETAILS SEE LINE LIST. 2. FOR VENT, DRAIN OR INSTRUMENT CONNECTION DETAILS SEE 45-L-45-000-2-00-80102 304, dual grade 3. WELDING ACCORDING TO 45-L-45-000-2-00-80021 HEAT TREATMENT (PWHT) N 5. CODE SHOWN IN BOM BETWEEN "<" & ">" DENOTES REPSOL UNICODE. "<N/A>" MEANS UNICODE IS "NOT AVAILABLE" PAINTING SCHEME (3) CONTRACTOR: CONTRACTOR DRAWING NUMBER: PROJECT: NR PIPING CLASS 4001008 4274-XH-DL-2121IA91F63-6 6C4 WELDING CLASS (4) LOW LINEAL DENSITY POLYETHILENE (PEL) CLIENT / COMPLEX AND POLYPROPYLENE (PP) PLANTS REPSOL POLYMEROS/ PED CATEGORY FOR PROJECT - ALBA PROJECT REPSQL Art 4.3 INSULATION CODE / THK. (mm) DRAWING NUMBER ANNEX 01 19-000-2-02-00001 sheet 2121IA91F63-6

BILL OF MATERIAL

	Signature fo on Iso li
	TITLE
et 106	ISOME

TRESS CALC. No

PIPE LAYOUT No

APPR. CLIENT

19-A-19-000-1-01-00001 she

19-L-19-000-2-00-86197 sheet 3

19-L-19-000-2-00-80602

or construction is shown ist of relevant CWA

LINE

2"-IA-91F63-6C4

APPROVED FOR

CONSTRUCTION

TRIC DRAWING

SINES INDUSTRIAL COMPLEX

FILENAME: 19-000-2-02-00001 sheet 2121IA91F63-6.dwg