REV. CAUSE ID: STREAM REV. NO.: 10 STREAM NO.:4303

REMARKS FOR MECHANICAL SUBCONTRACTOR:

1) LINES 1.1/2" AND SMALLER SHALL BE SUPPORTED IN FIELD IF NOT OTHERWISE INDICATED.

DESCRIPTION

I DENOTES PARTS LIST NO PIPE SUPPORT —

CROSSING BETWEEN WELDS ON PIPELINE SHALL NOT BE ADMITTED

SUPPORTS LEGEND:

REV.

ISSUED FOR REFERENCE

2)

ALL DIMENSION AND PROPER CONFIGURATION FOR LINES NPS 1.1/2" AND SMALLER SHALL BE CHECKED IN FIELD BEFORE CONSTRUCTION.

FOR THE COMPONENTS MARKED AS FIELD WELDED WITH THIS SYMBOL ✗ , ONE WELD FOR ADJUSTMENT OF IN LINE COMPONENT MUST BE LEFT

9) WHERE EARTHING BONDING IS REQUIRED, MECHANICAL SUBCONTRACTOR TO PERFORM IT BASED ON DOC. 45-P-000-7-06-00902/ 4274 -NN-DW-00000002 AND ASSEMBLY NO FEA005 AND FE019.

25-AUG-23

U.CHAVAN

A=RESTING SUPPORT G=GUIDE F=AXIAL STOP B=ANCHOR M=SPRING S=TEFLON PAD WHERE A WITHOUT NUMBERING IS INDICATED, THIS MEANS THAT THERE IS A REST DIRECTLY ON STEEL STRUCTURE.

P.VAZE

CHECK BY

G.PAGANON

APPR. BY

4) FOR EXTRA PIPE LENGTH REFER TO 4274-LZ-PC-00000603.
5) GUSSETING TO BE IMPLEMENTED BY MECHANICAL SUBCONTRACTOR AS PER 45-L-45-000-2-00-80004 / 4274-XH-SG-00000002.

(7) IN CASE OF DISCREPANCIES BETWEEN DATA SHOWN ON ISO AND IN LINE LIST (AS APPLICABLE, DATA SHOWN IN LINE LIST GOVERN.

8) ACTUAL CUT LENGTH OF PIPE AND FIELD WELDS SHALL BE DEFINED BY MECHANICAL SUBCONTRACTOR (REF.TO 4274-LZ-PC-00000603

E 139521663 N 113394950 SEE ISO 2121-LPN40Z19-1 8 STEM UP N 113394950 F4 G5 B7 F4 G5 ALLIGNMENT BOLTS SUPPLIED BY VALVE VENDOR F4 G5 B6 F4 G5 B6 8 STEM NORTH TE SEE ISO 2121-FO40M01-1 SPEC 1C17 E 139521663

BILL OF MATERIAL HOLD COMPONENT DESCRIPTION ITEM CODE QTY (IN) STATUS PIPE - A106-B PE SMLS T01AC03Z02 S-XS < PIPA010A11/2XS > (L-6679) I132777 FITTINGS TEE ASME B16.11 3000# A105N SWE SWE - R11FNC441101 NREQD < TESA300LBK1/2> 1/2X1/2 I1651299 PLUG ROUND HEAD ASME B16.11 - A105N MTE NREQD - R42FQC44W001 NREQD I10088243 <PLUA300CK1/2>(L-77) FLANGES SW FLANGE ASME B16.5 150# A105N RFFE SWE 125 - 250 AARH F02CDC44B105 S-XS I5378341 <SWFA300R151/2XS> (L-295) SPIRAL WOUND GASKET ASME B16 20 150# RETBE 304/GRAFOIL CARBON STEEL SS 304 1/2 163508894 ASME B16.5 G03GDP1IS12 < N/A> (N/A) BOLTS STUD BOLTS&NUTS ASME B18.31.2/ B18.2.2 A193-B7/A194-2H INCH SIZE I010B0301 I53437179 <SB2R51G1/221/2> - 2 NUTS PER BOLT - 60 mm Length STUD BOLTS&NUTS ASME B18.31.2/ B18.2.2 A193-B7/A194-2H INCH SIZE I010B0301 153437223 <SB2R51G1/231/4> - 2 NUTS PER BOLT - 80 mm Length ALVES / IN-LINE ITEMS BALL VALVE API 608 150# A216-WCB RFFE 316/R-PTFE, GF B7/2H 125 - 250 AARH I10013685 2PSB-FULL BORE FLOATING BALL OHW ASME B16.5 V04JDC29BZZG NREOD < N/A> (N/A) DISC CHECK WFR VALVE ASME B16.34 150# A216-WCB RFTBE 316/R-PTFE, GF 125 -I10016146 250 AARH SL VERTICAL&HORIZONTAL CRACK. PRESS. 1/2 PSI ASME B16.5 V40JDC29P01 NREOD <N/A> (N/A) BALL VALVE ASME B16.34 800# A105N SWE FTE 316/R-PTFE, GF 3PSB-RED BORE I67130076 FLOATING BALL OHW FIRE SAFE : API 607 & ANTISTATIC DEVICES "A60T series" TEAL V04JIC44126IG NREQD <N/A> (N/A) PIPE MATERIAL NOTES: 1. FOR TECHNICAL DETAILS SEE LINE LIST. 2. FOR VENT, DRAIN OR INSTRUMENT CONNECTION DETAILS SEE 45-L-45-000-2-00-80102 CS 3. WELDING ACCORDING TO 45-L-45-000-2-00-80021 HEAT TREATMENT (PWHT) 5. CODE SHOWN IN BOM BETWEEN "<" & ">" DENOTES REPSOL UNICODE. "<N/A>" MEANS UNICODE IS "NOT AVAILABLE" PAINTING SCHEME (3) CONTRACTOR: CONTRACTOR DRAWING NUMBER: PROJECT: PIPING CLASS 4001008 4274-XH-DL-2121FO40M01-2 1C17 WELDING CLASS (4) LOW LINEAL DENSITY POLYETHILENE (PEL) CLIENT / COMPLEX AND POLYPROPYLENE (PP) PLANTS REPSOL POLYMEROS/ FOR PROJECT - ALBA PROJECT SINES INDUSTRIAL COMPLEX Art 4.3 REPSQL DRAWING NUMBER ANNEX 00 19-000-2-02-00001 sheet 2121FO40M01-2

ISSUED FOR

REFERENCE

Signature for construction is shown 19-A-19-000-1-01-00001 sheet 43

TRESS CALC. No

PIPE LAYOUT No

APPR. CLIENT

19-L-19-000-2-00-80602

19-L-19-000-2-00-86197 sheet 2

PED CATEGORY INSULATION CODE / THK. (mm)

FILENAME: 19-000-2-02-00001 sheet 2121FO40M01-2.dwg