SEE ISO 2121-VA40U08-1 E 139536593 EL +26914 3/4X3/4"NPD 3MM OFFSET: F5 G6 B7 SEE ISO 2121-VG40E10-3 SPEC 2E63 E 139536950 N 113385463

BILL OF MATERIAL HOLD COMPONENT DESCRIPTION ITEM CODE QTY STATUS (IN) PIPE - A312-TP304/304L DUAL GR PE SMLS T01AL2CZ02 S-40S < PIPB04DA2140S > 12257939 (L-PIP111) ECCENTRIC SWAGE MSS SP-95 - A182-F304/304L DUAL GR PE PE SMLS SCH1-40S 1X3/4 158060789 SCH2-40S R22FQL2AZZ04 <ESWB04DAR12011101> (L-ESW23) 90 ELBOW ASME B16.11 3000# A182-F304/304L DUAL GR SWE SWE - R31FNL2A1103 I2258117 NREQD <90FB450LBK1> (L-90F05) COUPLING ASME B16.11 3000# A182-F304/304L DUAL GR SWE SWE - R01FNL2A1101 I2258105 NREOD <FCPB450LBK1> (L-FCP08) SW FLANGE ASME B16.5 300# A182-F316/316L DUAL GR RFFE SWE 125 - 250 AARH 12500941 F02CFL1MB105 S-40S <SWFB34DR35140S> (L-SWF37) SASKETS SPIRAL WOUND GASKET ASME B16.20 300# RFTBE 304/PTFE SS 304 SS 304 ASME I219568 B16.5 G03GFP1IG04 < N/A > (N/A) BOLTS STUD BOLTS&NUTS ASME B18.31.2/ B18.2.2 A320-L7/A194-7 INCH SIZE I010B5301 155705037 <SB2R55G5/831/4> - 2 NUTS PER BOLT - 80 mm Length VALVES / IN-LINE ITEMS GATE VALVE API 602 300# A182-F316/316L DUAL GR RFFE 12-316&HF SPW-316/PTFE 164004275 A193-B8M CL2/8MA 125 - 250 AARH BB-OS&Y SOW PTFE HW ASME B16.5 V01GFL1MB511 NREQD <G41L-AL017> (L-AL017)

2023 09:28:13 STRI	REMARKS FOR MECHANICAL SUBCONTRACTOR: 1) LINES 1.1/2" AND SMALLER SHALL BE SUPPORTED IN FIELD IF NOT OTHERWISE INDICATED. 2) ALL DIMENSION AND PROPER CONFIGURATION FOR LINES NPS 1.1/2" AND SMALLER SHALL BE CHECKED IN FIELD BEFORE CONSTRUCTION. 3) FOR THE COMPONENTS MARKED AS FIELD WELDED WITH THIS SYMBOL ✗ , ONE WELD FOR ADJUSTMENT OF IN LINE COMPONENT MUST BE LEFT 4) FOR EXTRA PIPE LENGTH REFER TO 4274-LZ-PC-00000603. 5) GUSSETING TO BE IMPLEMENTED BY MECHANICAL SUBCONTRACTOR AS PER 45-L-45-000-2-00-80004 / 4274-XH-SG-00000002. 6) CROSSING BETWEEN WELDS ON PIPELINE SHALL NOT BE ADMITTED. 7) IN CASE OF DISCREPANCIES BETWEEN DATA SHOWN ON ISO AND IN LINE LIST (AS APPLICABLE, DATA SHOWN IN LINE LIST GOVERN. 8) ACTUAL CUT LENGTH OF PIPE AND FIELD WELDS SHALL BE DEFINED BY MECHANICAL SUBCONTRACTOR (REF. TO 4274-LZ-PC-000000603). 9) WHERE EARTHING BONDING IS REQUIRED, MECHANICAL SUBCONTRACTOR TO PERFORM IT BASED ON DOC. 45-P-0007-706-000904 / 4274-NN-DW-00000002 AND ASSEMBLY NO FEA00S AND F019. SUPPORTS LEGEND: 1 DENOTES PARTSLIST NO PIPE ARSTINGSUPPORT G-GUIDE F-AXIAL STOP B-ANCHOR M-SPRING S-TEFLONPAD WHERE[A] WITHOUT NUMBERNING IS INDICATED. THIS MEANS THAT THERE IS A REST DIRECTLY ON STEEL STRUCTURE.							S	
-90-8								STRESS CALC. Nº	TIT
ATE: 2								P & ID 19-A-19-000-1-01-00001 sheet 35] I
Ď	00	ISSUED FOR REFERENCE	30-JUN-23	U.CHAVAN	P.VAZE	G.PAGANONI		LINE LIST N° 19-L-19-000-2-00-80602	
EXTR.	REV.	DESCRIPTION	DATE	DRW. BY	CHECK BY	APPR. BY	APPR. CLIENT	PIPE LAYOUT N° 19-L-19-000-2-00-86196 sheet 7	

Signature for construction is shown on Iso list of relevant CWA

ISSUED FOR

REFERENCE

ISOMETRIC DRAWING LINE

1"-VG-40E10-2E63

NOTES: 1. FOR TECHNICAL DETAILS SEE LINE LIST.

REPSQL

ANNEX

Art 4.3

PIPE MATERIAL

CS, low temperature

INSULATION CODE / THK. (mm)

HEAT TREATMENT (PWHT)

2. FOR VENT, DRAIN OR INSTRUMENT CONNECTION DETAILS SEE 45-L-45-000-2-00-80102

3. WELDING ACCORDING TO 45-L-45-000-2-00-80021

5. CODE SHOWN IN BOM BETWEEN "<" & ">" DENOTES REPSOL UNICODE. "<N/A>" MEANS UNICODE IS "NOT AVAILABLE"

19-000-2-02-00001 sheet 2121VG40E10-4

PAINTING SCHEME (3) CONTRACTOR: CONTRACTOR DRAWING NUMBER: PROJECT: NR

PIPING CLASS 4274-XH-DL-2121VG40E10-4 2E63 WELDING CLASS (4) LOW LINEAL DENSITY POLYETHILENE (PEL) AND POLYPROPYLENE (PP) PLANTS PED CATEGORY

FOR PROJECT - ALBA PROJECT

DRAWING NUMBER

CLIENT / COMPLEX REPSOL POLYMEROS/ SINES INDUSTRIAL COMPLEX

00

4001008

STREAM REV. NO.: 9 STREAM NO.:4554