REV. CAUSE ID:

STREAM REV. NO.: 7

STREAM NO.:4402 SUPPORTS LEGEND:

REV.

ISSUED FOR REFERENCE

DESCRIPTION

4) FOR EXTRA PIPE LENGTH REFER TO 4274-LZ-PC-00000603.
5) GUSSETING TO BE IMPLEMENTED BY MECHANICAL SUBCONTRACTOR AS PER 45-L-45-000-2-00-80004 / 4274-XH-SG-00000002.

6) CROSSING BETWEEN WELDS ON PIPELINE SHALL NOT BE ADMITTED.
7) IN CASE OF DISCREPANCIES BETWEEN DATA SHOWN ON ISO AND IN LINE LIST (AS APPLICABLE, DATA SHOWN IN LINE LIST GOVERN.

8) ACTUAL CUT LENGTH OF PIPE AND FIELD WELDS SHALL BE DEFINED BY MECHANICAL SUBCONTRACTOR (REF.TO 4274-LZ-PC-00000603

OPEN END CUT TO 45 DEG SEE ISO 2121-VA40Z08-1 SPEC 1C17 E 139522009 N 113382658 2 3/4X3/4"NPD EL +15656 2121-VA40Z06-3 SPEC 1C17 E 139522009 N 113382637 REMARKS FOR MECHANICAL SUBCONTRACTOR:

1) LINES 1.1/2" AND SMALLER SHALL BE SUPPORTED IN FIELD IF NOT OTHERWISE INDICATED. 2) ALL DIMENSION AND PROPER CONFIGURATION FOR LINES NPS 1.1/2* AND SMALLER SHALL BE CHECKED IN FIELD BEFORE CONSTRUCTION.

3) FOR THE COMPONENTS MARKED AS FIELD WELDED WITH THIS SYMBOL

✓, ONE WELD FOR ADJUSTMENT OF IN LINE COMPONENT MUST BE LEFT

A=RESTING SUPPORT G=GUIDE F=AXIAL STOP B=ANCHOR M=SPRING S=TEFLON PAD WHERE A WITHOUT NUMBERING IS INDICATED, THIS MEANS THAT THERE IS A REST DIRECTLY ON STEEL STRUCTURE.

P.VAZE

CHECK BY

G.PAGANONI

APPR. BY

31-MAR-2023 M.YADAV

TRESS CALC. Nº

PIPE LAYOUT Nº

APPR. CLIENT

19-A-19-000-1-01-00001 sheet 51

19-L-19-000-2-00-86196 sheet 7

19-L-19-000-2-00-80602

BILL OF MATERIAL HOLD N.S. COMPONENT DESCRIPTION ITEM CODE QTY STATUS (IN) PIPE - A106-B PE SMLS T01AC03Z02 S-XS < PIPA010A13/4XS> (L-6679) I132785 FITTINGS TEE ASME B16.11 3000# A105N SWE SWE - R11FNC441101 NREQD <TESA300LBK3/4> 3/4X3/4 I1651300 90 ELBOW ASME B16.11 3000# A105N SWE SWE - R31FNC441103 NREQD I1651298 <90FA300LBK3/4> (L-178) COUPLING ASME B16.11 3000# A105N SWE SWE - R01FNC441101 NREQD I1651676 <FCPA300LBK3/4> (L-180) PIPE MATERIAL NOTES: 1. FOR TECHNICAL DETAILS SEE LINE LIST. 2. FOR VENT, DRAIN OR INSTRUMENT CONNECTION DETAILS SEE 45-L-45-000-2-00-80102 CS 3. WELDING ACCORDING TO 45-L-45-000-2-00-80021 HEAT TREATMENT (PWHT) 5. CODE SHOWN IN BOM BETWEEN "<" & ">" DENOTES REPSOL UNICODE. "<N/A>" MEANS UNICODE IS "NOT AVAILABLE" PAINTING SCHEME (3) CONTRACTOR: CONTRACTOR DRAWING NUMBER: PROJECT: Signature for construction is shown PIPING CLASS 4001008 4274-XH-DL-2121VA40Z08-2 on Iso list of relevant CWA 1C17 WELDING CLASS (4) LOW LINEAL DENSITY POLYETHILENE (PEL) CLIENT / COMPLEX AND POLYPROPYLENE (PP) PLANTS ISOMETRIC DRAWING REPSOL POLYMEROS/ PED CATEGORY FOR PROJECT - ALBA PROJECT SINES INDUSTRIAL COMPLEX Art 4.3 REPSQL INSULATION CODE / THK. (mm) ANNEX DRAWING NUMBER 00 19-000-2-02-00001 sheet 2121VA40Z08-2

ISSUED FOR

REFERENCE

LINE

3/4"-VA-40Z08-1C17