
REMARKS FOR MECHANICAL SUBCONTRACTOR:

1) LINES 1.1/2" AND SMALLER SHALL BE SUPPORTED IN FIELD IF NOT OTHERWISE INDICATED.



BILL OF MATERIAL HOLD COMPONENT DESCRIPTION ITEM CODE QTY STATUS (IN) FITTINGS SPECIALTY COMPONENT SP-22-241C0-01 1 INSTRUMENTS INSTRUMENT COMPONENT 19-KV-4102D 1 PIPE SUPPORTS SPECIALITY SUPPORT - SP-045 NIPPLE - - A106-B PE MTE SMLS LENGTH 100mm R03AQC03ZW04 S-160 I2221177 NTQA010E1110324> (L-7881) PLUG ROUND HEAD ASME BI6.11 - A105N MTE NREQD - R42FQC44W001 NREQD 110088232 <PLUA300CK3/4> (L-77) ASKETS SPIRAL WOUND GASKET ASME B16.20 300# RFFE 304/PTFE CARBON STEEL SS 304 ASME 12 163598752 B16.5 G03GFB1IG12 < SPAQ505R3EA12 > (L-SPA05) STUD BOLTS&NUTS ASME B18.31.2/ B18.2.2 A193-B7/A194-2H INCH SIZE I010B0301 153438074 <SB2R51G11/883/4> - 2 NUTS PER BOLT - 225 mm Length STUD BOLTS&NUTS ASME B18.31.2/ B18.2.2 A193-B7/A194-2H INCH SIZE $\,$ I010B0301 153438064 <SB2R51G11/863/4> - 2 NUTS PER BOLT - 175 mm Length ALVES / IN-LINE ITEMS BALL VALVE ASME B16.34 800# A105N SWE FTE 316/R-PTFE, GF 3PSB-RED BORE 166567923 FLOATING BALL OHW FIRE SAFE :API 607 & ANTISTATIC DEVICES "A60T series" TEAL V04JIC44126IG NREQD <N/A> (N/A)

	1) 21.) En les in 2 in les son elles de son out les in vois sine en les in les								
		2) ALL DIMENSION AND PROPER CONFIGURATION FOR LINES NPS 1.1/2" AND SMALLER SHALL BE CHECKED IN FIELD BEFORE CONSTRUCTION.								
	3) FOR	3) FOR THE COMPONENTS MARKED AS FIELD WELDED WITH THIS SYMBOL 🗶 , ONE WELD FOR ADJUSTMENT OF IN LINE COMPONENT MUST BE LEFT								
	4) FOR	4) FOR EXTRA PIPE LENGTH REFER TO 4274-LZ-PC-00000603. 5) GUSSETING TO BE IMPLEMENTED BY MECHANICAL SUBCONTRACTOR AS PER 45-L-45-000-2-00-80004 / 4274-XH-SG-00000002.								
	5) GUS									
	6) CRC	6) CROSSING BETWEEN WELDS ON PIPELINE SHALL NOT BE ADMITTED.								
	7) IN CASE OF DISCREPANCIES BETWEEN DATA SHOWN ON ISO AND IN LINE LIST (AS APPLICABLE, DATA SHOWN IN LINE LIST GOVERN.									
	8) ACTUAL CUT LENGTH OF PIPE AND FIELD WELDS SHALL BE DEFINED BY MECHANICAL SUBCONTRACTOR (REF.TO 4274-LZ-PC-00000603). 9) WHERE EARTHING BONDING IS REQUIRED, MECHANICAL SUBCONTRACTOR TO PERFORM IT BASED ON DOC. 45-P-0007-06-00902/ 4274 -NN-DW-00000002 AND ASSEMBLY NO FEA005 AND FE019.									
	TIDENOTES DADITALIST NO PIPE — A=RESTING SUPPORT G=GLIDE F=AXIAL STOP B=ANCHOR M=SPRING S=TEHLON PAD									
	SUPPORTS LEGEND: Denotes parts list no PIPE — A=RESTING SUPPORT G=GUDE F=AXIAL STOP B=ANCHOR M=SPRING S=TEHLON PAD WHERE A WITHOUT NUMBERING IS INDICATED, THIS MEANS THAT THERE IS A REST DIRECTLY ON STEEL STRUCTURE.									
WILELE WITHOUT WORDERING IS INDICATED, THIS SIEAR OF THAT THERE IS A REST DIRECTED ON STEELE STRUCTURE.									—	
								STRESS CALC. Nº	TI	
	02	ISSUED FOR CONSTRUCTION	22-SEP-23	M.YADAV	P.VAZE	G.PAGANONI		-		
								P & ID	1	
H	01	ISSUED FOR CONSTRUCTION	10-AUG-23	M.YADAV	P.VAZE	G.PAGANONI				
								19-A-19-000-1-01-00001 sheet 54		
	00	ISSUED FOR CONSTRUCTION	27-JAN-23	U.CHAVAN	P.VAZE	G.PAGANONI		LINE LIST Nº		
	00							19-L-19-000-2-00-80602		
								PIPE LAYOUT Nº	1	
	REV.	DESCRIPTION	DATE	DRW. BY	CHECK BY	APPR. BY	APPR. CLIENT	19-L-19-000-2-00-86197 sheet 3		

Signature for construction is shown on Iso list of relevant CWA

LINE

12"-VZ-41C01-1E64 (HA)

APPROVED FOR

CONSTRUCTION

WELDING CLASS (4) ISOMETRIC DRAWING PED CATEGORY INSULATION CODE / THK. (mm)

PIPE MATERIAL

HEAT TREATMENT (PWHT)

PAINTING SCHEME (3)

PIPING CLASS

CS

NOTES: 1. FOR TECHNICAL DETAILS SEE LINE LIST.

CONTRACTOR:

ANNEX

2. FOR VENT, DRAIN OR INSTRUMENT CONNECTION DETAILS SEE 45-L-45-000-2-00-80102

3. WELDING ACCORDING TO 45-L-45-000-2-00-80021

DRAWING NUMBER

5. CODE SHOWN IN BOM BETWEEN "<" & ">" DENOTES REPSOL UNICODE. "<N/A>" MEANS UNICODE IS "NOT AVAILABLE"


CONTRACTOR DRAWING NUMBER:

4274-XH-DL-2121VZ41C01-1 1E64 LOW LINEAL DENSITY POLYETHILENE (PEL) AND POLYPROPYLENE (PP) PLANTS FOR PROJECT - ALBA PROJECT Art 4.3 REPSQL

CLIENT / COMPLEX REPSOL POLYMEROS/ SINES INDUSTRIAL COMPLEX

PROJECT:

4001008



19-000-2-02-00001 sheet 2121VZ41C01-1