REMARKS FOR MECHANICAL SUBCONTRACTOR:

1) LINES 1.1/2" AND SMALLER SHALL BE SUPPORTED IN FIELD IF NOT OTHERWISE INDICATED. PIPE MATERIAL NOTES: 1. FOR TECHNICAL DETAILS SEE LINE LIST. **ISSUED FOR** 2. FOR VENT, DRAIN OR INSTRUMENT CONNECTION DETAILS SEE 45-L-45-000-2-00-80102 2)

ALL DIMENSION AND PROPER CONFIGURATION FOR LINES NPS 1.1/2" AND SMALLER SHALL BE CHECKED IN FIELD BEFORE CONSTRUCTION.

FOR THE COMPONENTS MARKED AS FIELD WELDED WITH THIS SYMBOL ✗ , ONE WELD FOR ADJUSTMENT OF IN LINE COMPONENT MUST BE LEFT CS, Galvanized 3. WELDING ACCORDING TO 45-L-45-000-2-00-80021 REFERENCE 4) FOR EXTRA PIPE LENGTH REFER TO 4274-LZ-PC-00000603.
5) GUSSETING TO BE IMPLEMENTED BY MECHANICAL SUBCONTRACTOR AS PER 45-L-45-000-2-00-80004 / 4274-XH-SG-00000002. HEAT TREATMENT (PWHT) 6) CROSSING BETWEEN WELDS ON PIPELINE SHALL NOT BE ADMITTED.
7) IN CASE OF DISCREPANCIES BETWEEN DATA SHOWN ON ISO AND IN LINE LIST (AS APPLICABLE, DATA SHOWN IN LINE LIST GOVERN. PAINTING SCHEME (3) CONTRACTOR: CONTRACTOR DRAWING NUMBER: PROJECT: 8) ACTUAL CUT LENGTH OF PIPE AND FIELD WELDS SHALL BE DEFINED BY MECHANICAL SUBCONTRACTOR (REF.TO 4274-LZ-PC-00000603 Signature for construction is shown A=RESTING SUPPORT G=GUIDE F=AXIAL STOP B=ANCHOR M=SPRING S=TEFLON PAD WHERE A WITHOUT NUMBERING IS INDICATED, THIS MEANS THAT THERE IS A REST DIRECTLY ON STEEL STRUCTURE. PIPING CLASS 4001008 4274-XH-DL-2121IA68W11-11 SUPPORTS LEGEND: on Iso list of relevant CWA TRESS CALC. Nº WELDING CLASS (4) LOW LINEAL DENSITY POLYETHILENE (PEL) AND POLYPROPYLENE (PP) PLANTS ISOMETRIC DRAWING PED CATEGORY 19-A-19-000-1-01-00001 sheet 124 FOR PROJECT - ALBA PROJECT REPSQL LINE Art 4.3 ISSUED FOR REFERENCE 16-JUN-2023 M.YADAV P.VAZE G.PAGANONI 19-L-19-000-2-00-80602 INSULATION CODE / THK. (mm) DRAWING NUMBER ANNEX PIPE LAYOUT No 1"-IA-68W11-B-13 19-000-2-02-00001 sheet 2121IA68W11-11 APPR. CLIENT REV. DESCRIPTION CHECK BY APPR. BY 19-L-19-000-2-00-86197 sheet 4 FILENAME: 19-000-2-02-00001 sheet 2121IA68W11-11.dwg