4) FOR EXTRA PIPE LENGTH REFER TO 4274-LZ-PC-00000603.
5) GUSSETING TO BE IMPLEMENTED BY MECHANICAL SUBCONTRACTOR AS PER 45-L-45-000-2-00-80004 / 4274-XH-SG-00000002.

□ DENOTES PARTS LIST NO PIPE SUPPORT —

DESCRIPTION

() CROSSING BETWEEN WEEDS ON THE ELING STALE NOT BE ADMITTED.

7) IN CASE OF DISCREPANCIES BETWEEN DATA SHOWN ON ISO AND IN LINE LIST (AS APPLICABLE, DATA SHOWN IN LINE LIST GOVERN.

8) ACTUAL CUT LENGTH OF PIPE AND FIELD WELDS SHALL BE DEFINED BY MECHANICAL SUBCONTRACTOR (REF.TO 4274-LZ-PC-00000603


6) CROSSING BETWEEN WELDS ON PIPELINE SHALL NOT BE ADMITTED.

SUPPORTS LEGEND:

REV.

ISSUED FOR REFERENCE

ISSUED FOR REFERENCE



A=RESTING SUPPORT G=GUIDE F=AXIAL STOP B=ANCHOR M=SPRING S=TEFLON PAD WHERE A WITHOUT NUMBERING IS INDICATED, THIS MEANS THAT THERE IS A REST DIRECTLY ON STEEL STRUCTURE.

P.VAZE

P.VAZE

CHECK BY

U.CHAVAN

U.CHAVAN

08-DEC-23

30-JUN-23

G.PAGANONI

G.PAGANONI

APPR. BY

TRESS CALC. No

PIPE LAYOUT No

APPR. CLIENT

19-A-19-000-1-01-00001 sheet 29

19-L-19-000-2-00-86196 sheet 5

19-L-19-000-2-00-80602

BILL OF MATERIAL HOLD COMPONENT DESCRIPTION ITEM CODE QTY (IN) STATUS PIPE - A106-B PE SMLS T01AC03Z02 S-XS < PIPA010A13/4XS > (L-6679) 3/4 I132785 0.2 M PIPE - A106-B PE SMLS T01AC03Z02 S-XS < PIPA010A11/2XS > (L-6679) 1/2 I132777 0.1 M REDUCING TEE ASME B16.11 3000# A105N SWE SWE - R12FNC441101 NREQD 3/4X1/2 I1651303 <RTEA300KBK3/41/2>(L-RTE15) NIPPLE - - A106-B PE MTE SMLS LENGTH 100mm R03AQC03ZW04 S-160 I2221177 <NTOA010E1110324> (L-7881) PLUG ROUND HEAD ASME B16.11 - A105N MTE NREQD - R42FQC44W001 NREQD 110088232 <PLUA300CK3/4> (L-77) SW FLANGE ASME B16.5 300# A105N RFFE SWE 125 - 250 AARH F02CFC44B105 S-XS 19762189 <SWFA300R351/2XS> (L-375) ASKETS SPIRAL WOUND GASKET ASME B16.20 300# RFTBE 316/GRAFOIL CARBON STEEL SS 316 1/2 I60205405 ASME B16.5 G03GFP1IQ01 < SPAQ504R3EA1/2> (L-SPA01) STUD BOLTS&NUTS ASME B18.31.2/ B18.2.2 A193-B7/A194-2H INCH SIZE I010B0301 153437190 <SB2R51G1/221/2> - 2 NUTS PER BOLT - 65 mm Length VALVES / IN-LINE ITEMS BALL VALVE API 608 800# A105N FTE FTE 316/PEEK B7/2H 125 - 250 AARH 166130989 2PSB-FULL BORE FLOATING BALL OHW V04JIC4422NN1 NREQD <N/A> (N/A) BALL VALVE API 608 300# A216-WCB RFFE 316/PEEK B7/2H 125 - 250 AARH I64811253 2PSB-FULL BORE FLOATING BALL OHW ASME B16.5 V04JFC29BNN NREQD <N/A> (N/A) 1 INSTRUMENT COMPONENT 1/2 19-FT-4013A 1 PIPE MATERIAL NOTES: 1. FOR TECHNICAL DETAILS SEE LINE LIST. 2. FOR VENT, DRAIN OR INSTRUMENT CONNECTION DETAILS SEE 45-L-45-000-2-00-80102 CS 3. WELDING ACCORDING TO 45-L-45-000-2-00-80021 HEAT TREATMENT (PWHT) 5. CODE SHOWN IN BOM BETWEEN "<" & ">" DENOTES REPSOL UNICODE. "<N/A>" MEANS UNICODE IS "NOT AVAILABLE" PAINTING SCHEME (3) CONTRACTOR: CONTRACTOR DRAWING NUMBER: PROJECT: PIPING CLASS 4001008 4274-XH-DL-2121CYG40C05-7 1E22 WELDING CLASS (4) LOW LINEAL DENSITY POLYETHILENE (PEL) CLIENT / COMPLEX AND POLYPROPYLENE (PP) PLANTS REPSOL POLYMEROS/ PED CATEGORY FOR PROJECT - ALBA PROJECT SINES INDUSTRIAL COMPLEX REPSQL INSULATION CODE / THK. (mm) DRAWING NUMBER ANNEX 01 19-000-2-02-00001 sheet 2121CYG40C05-7

Signature for construction is shown

on Iso list of relevant CWA

ISOMETRIC DRAWING

LINE

3/4"-CYG-40C05-1E22 (PS)

FILENAME: 19-000-2-02-00001 sheet 2121CYG40C05-7.dwg