REV. CAUSE ID:

REV.

SUPPORTS LEGEND:

ISSUED FOR CONSTRUCTION

REMARKS FOR MECHANICAL SUBCONTRACTOR:

1) LINES 1.1/2" AND SMALLER SHALL BE SUPPORTED IN FIELD IF NOT OTHERWISE INDICATED.

DESCRIPTION

DENOTES PARTS LIST NO PIPE SUPPORT —

2) ALL DIMENSION AND PROPER CONFIGURATION FOR LINES NPS 1.1/2" AND SMALLER SHALL BE CHECKED IN FIELD BEFORE CONSTRUCTION.
3) FOR THE COMPONENTS MARKED AS FIELD WELDED WITH THIS SYMBOL ✗, ONE WELD FOR ADJUSTMENT OF IN LINE COMPONENT MUST BE LEFT

4) FOR EXTRA PIPE LENGTH REFER TO 4274-LZ-PC-00000603.
5) GUSSETING TO BE IMPLEMENTED BY MECHANICAL SUBCONTRACTOR AS PER 45-L-45-000-2-00-80004 / 4274-XH-SG-00000002.

6) CROSSING BETWEEN WELDS ON PIPELINE SHALL NOT BE ADMITTED.
7) IN CASE OF DISCREPANCIES BETWEEN DATA SHOWN ON ISO AND IN LINE LIST (AS APPLICABLE, DATA SHOWN IN LINE LIST GOVERN.

8) ACTUAL CUT LENGTH OF PIPE AND FIELD WELDS SHALL BE DEFINED BY MECHANICAL SUBCONTRACTOR (REF.TO 4274-LZ-PC-00000603

SEE ISO 2121-VG40Z03-1 SPEC 1C17 E 139520150 N 113394255 F4 2"NPD 2121-VG40Z03-3 E 139520150 F4 G5 B6 EL +9582 CONN TO 19-D-4083/B 2/in/RFFE/150 N 113395150

A=RESTING SUPPORT G=GUIDE F=AXIAL STOP B=ANCHOR M=SPRING S=TEFLON PAD WHERE A WITHOUT NUMBERING IS INDICATED, THIS MEANS THAT THERE IS A REST DIRECTLY ON STEEL STRUCTURE.

P.VAZE

CHECK BY

G.PAGANONI

APPR. BY

16-DEC-22

M.YADAV

TRESS CALC. Nº

PIPE LAYOUT Nº

APPR. CLIENT

19-L-19-000-2-00-80602

19-L-19-000-2-00-86197 sheet 3

BILL OF MATERIAL HOLD COMPONENT DESCRIPTION STATUS ITEM CODE QTY (IN) PIPE - A106-B BE SMLS T01AC03V02 S-STD < PIPA010B12STD > (L-7806) I117862 FITTINGS 45 LATERAL YH-ST-C05 A234-WPB BE - C33EC04V01 S-STD x <N/A> (N/A). I210549 45 LR ELBOW ASME B16.9 A234-WPB BE SMLS C02DC04V01 S-STD <45LA200F32STD> I210283 FLANGES WN FLANGE ASME B16.5 150# A105N RFFE BE 125 - 250 AARH F01CDC44BV05 S-STD 15355795 <WNFA300R152STD> (L-149). GASKETS SPIRAL WOUND GASKET ASME B16.20 150# RFTBE 304/GRAFOIL CARBON STEEL SS 304 2 I63508906 ASME B16.5 G03GDP1IS12 < N/A> (N/A) BOLTS STUD BOLTS&NUTS ASME B18.31.2/ B18.2.2 A193-B7/A194-2H INCH SIZE I010B0301 153437429 <SB2R51G5/831/2> - 2 NUTS PER BOLT - 85 mm Length PIPE MATERIAL NOTES: 1. FOR TECHNICAL DETAILS SEE LINE LIST. 2. FOR VENT, DRAIN OR INSTRUMENT CONNECTION DETAILS SEE 45-L-45-000-2-00-80102 CS 3. WELDING ACCORDING TO 45-L-45-000-2-00-80021 HEAT TREATMENT (PWHT) 5. CODE SHOWN IN BOM BETWEEN "<" & ">" DENOTES REPSOL UNICODE. "<N/A>" MEANS UNICODE IS "NOT AVAILABLE" PAINTING SCHEME (3) CONTRACTOR: CONTRACTOR DRAWING NUMBER: PROJECT: PIPING CLASS 4001008 4274-XH-DL-2121VG40Z03-2 WELDING CLASS (4) LOW LINEAL DENSITY POLYETHILENE (PEL) CLIENT / COMPLEX AND POLYPROPYLENE (PP) PLANTS REPSOL POLYMEROS/ PED CATEGORY FOR PROJECT - ALBA PROJECT SINES INDUSTRIAL COMPLEX REPSQL Art 4.3 INSULATION CODE / THK. (mm) DRAWING NUMBER ANNEX 00 19-000-2-02-00001 sheet 2121VG40Z03-2

APPROVED FOR

CONSTRUCTION

FILENAME: 19-000-2-02-00001 sheet 2121VG40Z03-2.dwg