



**ROCKFORD BOARD OF EDUCATION
INVITATION FOR BID ON SUPPLIES, MATERIALS, EQUIPMENT OR SERVICES
FOR SCHOOL DISTRICT NO. 205
ROCKFORD, ILLINOIS**

IFB No. **24-59 Auburn H.S. Field House Locker Rooms**

DATE: **May 19, 2024**

RE: **ADDENDUM NO. 1**

To All Bidders:

Included are modifications, clarifications and/or corrections for the Project Manual and are hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

If you plan to hand deliver your IFB submission on the due date, please note you must check in on the 1st floor prior to coming to the bid opening. Please allow time for this as late submission will not be accepted.

Refer all questions relative to the business aspect, Instructions to Bidders, Special Conditions, and questions concerning the technical aspect of the documents to the Director of Purchasing by email at purchasingdeptstaff@rps205.com.

ROCKFORD BOARD OF EDUCATION

By: Dane Youngblood
Director of Purchasing



4615 E. State Street Suite 206 Rockford Illinois 61108
815 / 397-3330

ADDENDUM NO. 1
05.17.24

Project: **RPS 205 Field House Locker Room Build-Out**
RPS Project No. 2414 / IFB No. 24-59

To: All Bidders

This addendum is issued to modify, clarify, or correct the original Project Manual and/or Drawings and is hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

Attachments

1. Addendum Documents- Pre-Bid Meeting Minutes, Specification and Drawing Clarifications (11 pages)



To: **All Bidders:**

Date: **05.17.24**

Project: **RPS 205 Field House Locker Room Build-Out**
RPS205 Project No. 2414/IFB No. 24-59

Subject: **Addendum No. 1**

Architect: **Hagney Architects, LLC**
4615 East State St Suite 206
Rockford, IL 61108

This addendum forms a part of the Bidding and Contract Documents and modifies the original Bidding Documents dated **05.03.24**. Acknowledge receipt of this addendum in space provided on Bid Form. FAILURE TO ACKNOWLEDGE RECEIPT OF ADDENDA ON THE BID FORM MAY DISQUALIFY BID.

This Addendum may include revised Project Manual pages and/or Drawings that are to be inserted in the correct sequence in the Bidding Documents.

Text deleted from the Project Manual by this Addendum is indicated by overstrike. Example:

~~Overstrike~~

Bold lettering indicates lines in which text has been modified or added by this Addendum.

Revisions to Drawings are identified by the Addendum number.
Cross-check all revised documents with the following:

Pre-Bid Meeting Minutes

Mandatory meeting took place on Tuesday, May 14, 2024 @ 10:00 AM at Auburn High School.

Introductions:

- Megan Simon, Construction Project Manager, Rockford Public Schools
- Frank St. Angel, Project Architect, Hagney Architects, LLC
- Anne Baldwin, Hagney Architects, LLC

1. General items:

- A. Megan read aloud the Pre-bid Conference Opening Statement as required by Purchasing; see attached.
- B. Megan clarified that the anticipated completion date is NOT this summer- due to late construction start date and product lead times. Please indicate your number of working days on the bid form. (A revised bid form will be included by addendum).
- C. The School would like the training room to be completed prior to the start of the school year for sports practice, if possible. If not possible, the school will adapt as needed.
- D. Working hours for the project can be 1st/2nd or 3rd shifts as needed. The build-out space is independent of student traffic and can be accessed directly from the outside.



Interior work requiring coordination/accessing existing utilities/panels/etc.- will require coordination with the school.

E. Badging process will be required for all workers/staff on site.

2. Schedule:

Bids Due: Tuesday, June 11, 2024 at 2:00 PM (CDST) Rockford Board of Education, 6th floor Conference Room, 501 Seventh St., Rockford, IL 61104. (see Invitation to Bid for specific information and check-in procedure if hand delivering your bid)
Last Bidding RFI: Accepted until: 12:00 P.M., June 4, 2024
Last Addendum: Issued by 4:30 P.M., June 6, 2024
PRS 205 Board Meeting: Decision, Tuesday, June 18, 2024
Award/Notice to Proceed: Wednesday, June 19, 2024
Substantial Completion: Date TBD
Final Completion: If possible, the Training Room to be complete by August 23, 2024. Final project completion date TBD- however, bidders to submit number of calendar days for construction on bid form.

3. General Scope Description:

1. Locker room shell was installed per a previous floor plan during the original field house construction, current plan has slight revisions requiring underslab utility re-work.
2. A description of the project "demo" scope was discussed, including selective demolition of underslab utilities, concrete slab areas, above utilities, cmu walls, HM doors and roof/metal decking for new RTU's.
3. A brief description of the "new" scope was discussed, including CMU walls, Structural Clay Tile walls, EIFS type acrylic plaster at the shower/toilet groups, stand alone training room with both exterior and interior access, HDPE changing stalls, toilet and shower partitions, metal lockers, areas of epoxy flooring (with coved base) and tile flooring.

6. To submit bidding RFI questions, including questions asked at this pre-bid meeting email to:

- PurchasingDeptStaff@rps205.com

7. Questions asked from meeting:

A. Is added steel required at the new RTU?

Response: yes, see structural drawings.

B. Is there an existing roof information or warranty?

Response: Roof is a 60-ml Versico "Versiweld" fully adhered roofing system ("white"), there was 20yr warranty(2013 install). Work to flash/roof at the new RTU locations can be



performed by any Versico certified roofing contractor, to assure the Warranty will not be voided.

C. Any other RPS work at the school that would impact this project?

Response: The AHS Roofing Project is currently out for bidding, however the roof above the locker rooms, is not part of the scope.

D. Who is responsible for clearing out the area of construction (build-out shell area that is presently filled with school storage)?

Response: The district is in process of removing everything from the space.

END OF PRE-BID MEETING MINUTES

SPECIFICATIONS

Specification Changes: The Specifications shall be ADDED or REVISED as follows:

1. TABLE OF CONTENTS (ADDED)- missing from spec manual

DRAWINGS

Drawing Changes: The Drawings shall be REVISED as follows:

1. Sheet A4.0, Toilet Accessory Schedule. See revised "basis of design" hand dryer with 360° rotating nozzle and separate ADA wall guard.

Hand Dryer: Saniflow "Automatic E88ACS-UL" (Steel Satin Finish)

Wall Guard: American Dryer "ADA-WG Wall Guard" (Satin Stainless Steel)

6	HAND DRYER -Saniflow Automatic	SANIFLOW	E88ACS-UL	3	-	1	1	3	-	-
	WALL GUARD- American Dryer ADA-WG Wall Guard	AMERICAN DRYER	WG- Satin							

BN-RFI Responses

(note that responses to the questions below may be "written only" and have not been added in the specification or drawing revisions above- however the response is to be incorporated into the project documents)

BN-RFI #1 Concrete Moisture Mitigation?

1. Waterproofing Admix Substitution Submitted. Please consider updating your specifications for future projects to include **ISE Logik MVRA 900** and include as an "equal" in an upcoming addendum for this project. Note that the specified "Vapor Lock 20/20 will not meet "Buy America" standards if applicable.

Response-

- **MVRA 900 Moisture Vapor Reduction Admixture is Accepted, subject to full compliance with the specifications.**
- **"Buy America" standards do not apply to this project.**

BN-RFI #2 Hand Dryer Substitution request?

1. Saniflow "Machflow M09A" Hand dryer substitution request submitted, along with "U-Flow" hand dryer.

Response- Both dryers are not accepted- please see revised "basis of design" hand dryer this addendum.

BN-RFI #3 Training Rm new exterior door

1. Door F147A is listed as an aluminum frame type AL-1 and an aluminum door type V. Type V doors are narrow lite doors. These are usually HM or Wood. So I would like to verify that this is to be an aluminum door. And if so, do they want us to glaze in a metal panel and cut in a narrow lite kit?

Response- Please revise door and frame from AL to HM: Opening F147A to be Hollow Metal exterior door with a vision panel, frame sim. to AL-1- however Hollow Metal.

BN-RFI #4 General Door and Hardware Questions

1. What are the door veneer details as required to match existing?
2. Is there a specific cylinder and keyway system that is required to be provided or will these be supplied by the school system and only require locks less cores?
3. When will this project roughly need frames and doors onsite?

Response-

1. **"Clear maple" is the RPS 205 standard for door veneer.**
2. **Provide and install "Schlage ND", Keyway "Sargent LK"**
3. **Please refer to project schedule discussion from pre-bid meeting notes**

BN-RFI #5 Door and Ceiling Questions

1. *For Suspended Acrylic plaster finish ceilings*, I will provide the Armstrong Stucco/Grid System. All other work by plaster contractor, mesh, base coat, and finish coat. Sound good?
2. *For Suspended Gypsum Board-Veneer plaster ceilings*, they do not make an abuse resistant that you can plaster. I'd suggest we use a Kal-kote plaster board, then once the veneer is applied it's basically resistant. Make sense? Bonding to regular abuse resistant drywall isn't suggested by KOJA, unless plaster contractor is ok with it.
3. *Per 1/A5.2, it states patch stud wall*, do we have work there, looks like CMU or precast?
4. *Armstrong Kitchen Zone tile* does not meet the architect's specs. It's only 5/8" thick and CAC is 33. See below and attached product data.

Response-

1. **Not a question for A/E- GC Coordinate.**
2. **"Kal-Kote" plaster board/veneer plaster is acceptable.**
3. **Note refers to the existing stud/gwb wall infill and HM door- both to be demolished. The "patch/paint" note is for any patching/painting required at the existing precast wall panel opening due to the removal of the wall/door.**
4. **Revise Specification Section 095123 2.3 Acoustical Tiles, A Manufacturers: Armstrong; "Ceramaguard Fine Fissured"- Perforated 24"x24" panel (SEE BELOW)**



2.3 ACOUSTICAL TILES

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. **Armstrong World Industries, Inc.; “CERAMAGUARD FINE FISSURED”-PERFORATED 24” x 24” PANELS.**
- B. Classification: ASTM E 1264.
- C. Color: White.
 - 1. Type III, mineral base with painted finish; Form 1, modular.
- D. **LR: not less than .79.**
- E. **NRC: not less than .55**, Type E-400 mounting according to ASTM E 795.
- F. CAC: not less than 35.
- G. Edge/Joint Detail: **square** to fit flange of exposed suspension system members.
- H. **Thickness: 5/8 inch**

BN-RFI #6 Hand Dryer Substitution request?

- 1. I was looking at the Auburn HS Field House Locker Rooms project and noticed that the Excel XL-W with a recess kit is the basis of design. We are requesting that the World Dryer VERDEdri be approved as an equal to the Xlerator. Attached is a sub request, comparison sheet and spec sheet.

Response- Not accepted- please see revised “basis of design” hand dryer this addendum.

BN-RFI #7 Fire Alarm Panel

- 1. On page 488 of the specification referencing section 28 31 00 1.3 – 1.4 - Fire Alarm Systems. The existing system is being called out as a Notifier Onyx System. On the drawing E3.0 it is being called out as a Simplex system in the Responsibility Schedule. Please confirm the existing system. Please see attached drawing and spec sheet.

Response- The fire alarm panel is a Simplex 4100ES with voice capability.

ATTACHMENTS

Pre-Bid Conference Opening Statement (1 page)

Pre-Bid Meeting Sign-In Sheets (2 pages)

Table of Contents (3 pages)

END OF ADDENDUM NO. 1

PRE-BID CONFERENCE OPENING STATEMENT

Welcome to the mandatory pre-bid conference for IFB No. 24-59 Auburn H.S. Field House Locker Rooms for the Rockford Public Schools.

The purpose of this meeting is to receive input, comments, questions, clarifications and suggested changes relative to this solicitation. As a reminder, the only acceptable changes to the Bid/RFP are formal Addenda published by the RPS Purchasing department. Additionally, the Addendum may address other issues identified by the School District.

The goal of today's meeting is to increase your knowledge of the solicitation as it is written and provide an information mechanism in which you may advise the School District of any changes it should make. Consequently, any changes you wish the Rockford Public Schools to consider must be submitted in writing to the Purchasing department before the deadline as expressed in the solicitation.

We will try to answer as many of the questions as possible. If we cannot answer a question today, we will defer that answer to the published Addendum. Additionally, minutes from this pre-bid conference will be published in the Addendum.

- Bid Opening is scheduled for June 11, 2024 at 2:00 pm Rockford Board of Education, 6th floor Conference Room. Late bids will not be accepted. Faxed or emailed bids will not be accepted.
- Board Approval: June 18, 2024.
- Bid RFI Procedures - All written correspondence during the bid process **MUST** be sent to Dane Youngblood, Director of Purchasing, via email at PurchasingDeptStaff@rps205.com. Last RFI will be accepted until June 4, 2024 at 12:00 pm. Last addendum will be issued by June 6, 2024 at 4:30 pm.
- Addenda will be emailed to all attendees at the pre-bid conference, posted on the RPS website and Bonfire.
- PLEASE reference the **REQUIRED FORMS CHECK LIST** for all documents that **must** be submitted with your bid offer form. All forms must be properly completed, signed and submitted or your bid will be deemed non-responsive.



PRE-BID MEETING SIGN-IN SHEET

IFB No. 24-59 Auburn H.S. Field House Locker Rooms

PLEASE WRITE EMAIL ADDRESS SO THAT IT IS LEGIBLE IN ORDER TO RECEIVE ADDENDUM INFORMATION

	Printed Name	Company Name	Company Address	Telephone	E-mail
1	Ton McNamara	Larson & Larson Builders	5612 Industrial Ave Loves Park IL	815-633-1773	Estimating@LLBuilders.net
2	Todd Byxbee	Miller Eng Co.	1616 South Main St Rockford	815 963 4878	TByxbee@meccogroup.com
3	Jacob Leroux	Scardoli	1321 Capital Drive	815-962-4031	jacob.leroux@scardoli.com
4	Zac Zwierp	Mayer Eng	1616 S Main St Rockford	815 963 4878	22zwierp@meccogroup.com
5	Jenna Tipton	Sjostrom	1129 Harrison Ave, Rockford	815-226-0330	Estimating@SjostromConstruction.com
6	ERIC ELLIOTT	CMS			eric@CompleteMechanicalSolutions.com
7	Steno Johnson	CMS		815 218 5796	

ROCKFORD PUBLIC SCHOOLS
IFB No. 24-59 Auburn H.S. Field House Locker Rooms
Pre-Bid Meeting Sign-In Sheet
May 14, 2024 at 10:00 a.m.

	Printed Name	Company Name	Company Address	Telephone	E-mail
8	Mark Coffman	Automatic Fire	7910 Burden Rd	815-703-8276	MarkC@automatic-fire-systems.com
9	BRAD HANT	" "	" "	815-654-7448	BRAD@AUTOMATIC-FIRE-SYSTEMS.COM
10	DAVE DINGES	STENSTROM	2420 20 th STREET	815-509-7554	DAVED@RSTENSTROM.COM
11	SW VISTINE	Kelso-Burnett	3558 ELECTRIC AVE ROCKFORD IL	815-575-4294	SVISTINE@kelso-burnett.com
12	Arno Baldwin	Hagney Arch	4615 E State St	397-0173	
13	Joe Cimino	Rock valley Concrete Cutting	4235 S. Perryville Rd	815-222-2222	Will Roche @ Rock valley Concrete cutting.com
14	Frank Staveland	Hagney Arch	4615 E. State	397 3330	Franks@HagneyArchitects.com
15	MEGAN SIMON	RPS 205		815-378-3632	MEGAN.SIMON@RPS205.COM
16	Jake Schlichting	Dpi Construction	16961 Comly Rd. Pec	815-618-5837	Ryan@Dpi.construction
17					
18					
19					

Written Specifications - Table of Contents

DIVISION 00 - PROCUREMENT AND CONTRACTING REQUIREMENTS

00 4113 BID FORM AND RELATED SECTIONS – REFER TO “PART 1 BID” DOCUMENTS

DIVISION 01 - GENERAL REQUIREMENTS

01 1000 SUMMARY
01 1100 MISCELLANEOUS PROVISIONS
01 2500 SUBSTITUTION PROCEDURES
012500EVA SUBSTITUTION FORM
01 2600 CONTRACT MODIFICATION PROCEDURES
01 2900 PAYMENT PROCEDURES
01 3100 PROJECT MANAGEMENT AND COORDINATION
01 3200 CONSTRUCTION PROGRESS DOCUMENTATION
01 3300 SUBMITTAL PROCEDURES
01 5000 TEMPORARY FACILITIES AND CONTROLS
01 6000 PRODUCT REQUIREMENTS
01 7300 EXECUTION
01 7329 CUTTING AND PATCHING
01 7419 CONSTRUCTION WASTE MANAGEMENT AND DISPOSAL
01 7700 CLOSEOUT PROCEDURES
017839 OPERATION AND MAINTENANCE DATA
01 7839 PROJECT RECORD DOCUMENTS
01 7900 DEMONSTRATION AND TRAINING

DIVISION 02 – EXISTING CONDITIONS

02 4119 SELECTIVE DEMOLITION
02 4126 SELECTIVE ELECTRICAL DEMOLITION

DIVISION 03 - CONCRETE

03 3000 CAST-IN-PLACE CONCRETE

DIVISION 04 - MASONRY

04 2000 UNIT MASONRY

DIVISION 05 - METALS

NOT USED

DIVISION 06 – WOOD, PLASTICS AND COMPOSITES

06 1000 ROUGH CARPENTRY
06 4116 PLASTIC LAMINATE-CLAD ARCHITECTURAL CABINETS

DIVISION 07 – THERMAL AND MOISTURE PROTECTION

07 9200 JOINT SEALANTS

DIVISION 08 – OPENINGS

08 1113 HOLLOW METAL DOORS AND FRAMES
08 1416 FLUSH WOOD DOORS
08 7100 FINISH HARDWARE
08 8000 GLAZING

DIVISION 09 – FINISHES

09 2216	NON-STRUCTURAL METAL FRAMING
09 2513.13	ACRYLIC PLASTER FINISH (STO CORP.)
09 2613	GYPSUM VENEER PLASTERING
09 3000	TILING
09 5123	ACOUSTICAL TILE CEILINGS
09 6513	RESILIENT BASE AND ACCESSORIES
09 6723	RESINOUS FLOORING
09 6813	TILE CARPETING
09 9123	PAINTING

DIVISION 10 – THERMAL AND MOISTURE PROTECTION

10 1400	SIGNAGE
10 2113.19	PLASTIC TOILET COMPARTMENTS
10 2116.19	PLASTIC SHOWER AND DRESSING COMPARTMENTS
10 2800	TOILET, BATH AND LAUNDRY ACCESSORIES
10 4413	FIRE EXTINGUISHER CABINETS
10 4416	FIRE EXTINGUISHERS
10 5113	METAL LOCKERS

DIVISION 11 – EQUIPMENT

NOT USED

DIVISION 12 – EQUIPMENT

NOT USED

DIVISION 13 – SPECIAL CONSTRUCTION

NOT USED

DIVISION 14 – CONVEYING EQUIPMENT

NOT USED

DIVISION 21 – FIRE SUPPRESSION

21 0500	COMMON WORK RESULTS FOR FIRE SUPPRESSION
21 0553	IDENTIFICATION FOR FIRE SUPPRESSION PIPING AND EQUIPMENT
21 0590	TESTING OF FIRE SUPPRESSION PIPING
21 1313	WET PIPE SPRINKLER SYSTEMS

DIVISION 22 – PLUMBING

22 0503	PIPES AND TUBES FOR PLUMBING PIPING AND EQUIPMENT
22 0523	GENERAL DUTY VALVES FOR PLUMBING PIPING
22 0529	HANGERS AND SUPPORTS FOR PLUMBING PIPING AND EQUIPMENT
22 0553	IDENTIFICATION FOR PLUMBING PIPING AND EQUIPMENT
22 0590	TESTING OF PLUMBING PIPING
22 0700	PLUMBING INSULATION
22 1100	FACILITY WATER DISTRIBUTION
22 1300	FACILITY SANITARY SEWERAGE
22 4000	PLUMBING FIXTURES

DIVISION 23 – HEATING VENTING AND AIR CONDITIONING

23 0529	HANGERS AND SUPPORTS FOR HVAC PIPING AND EQUIPMENT
23 0548	IBRATION CONTROLS FOR HVAC EQUIPMENT
23 0553	IDENTIFICATION FOR HVAC PIPING AND EQUIPMENT

23 0593	TESTING, ADJUSTING AND BALANCING FOR HVAC
23 0700	HVAC INSULATION
23 0900	INSTRUMENTATION AND CONTROL FOR HVAC
23 0993	SEQUENCE OF OPERATIONS FOR HVAC CONTROLS
23 1123	FACILITY NATURAL GAS PIPING
23 3100	HVAC DUCTS AND CASINGS
23 3300	AIR DUCT ACCESSORIES
23 3700	AIR OUTLETS AND INLETS
23 8103	PACKAGED ROOFTOP AIR CONDITIONING UNITS WITH ENERGY WHEEL
23 8200	CONVECTION HEATING AND COOLING UNITS

DIVISION 24 – ELECTRICAL

24 0503	EQUIPMENT WIRING CONNECTIONS
24 0519	LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES
24 0529	HANGERS AND SUPPORTS FO ELECTRICAL SYSTEMS
26 0533	RACEWAY AND BOXES FOR ELECTRICAL SYSTEMS
26 0923	LIGHTING CONTROL DEVICES
26-2416	PANELBOARDS
26 2726	WIRING DEVICES
26 5100	INTERIOR LIGHTING

DIVISIONS 25 – 26

NOT USED

DIVISION 27 – COMMUNICATIONS

27 1343	COMMUNICATIONS SERVICES CABLING
---------	---------------------------------

DIVISION 28 – ELECTRONIC SAFETY AND SECURITY

28 3100	FIRE ALARM SYSTEM
---------	-------------------

END: TABLE OF CONTENTS