

Test Certificate

No. PPS2 00 095 23

- 1. Customer** AVANTE Ventilation Equipment L.L.C.
P.O Box 662447
Plot No.: 597-4242
Street No. 77
Dubai Investment Park 2
Dubai
UAE
- 1.1 Designation and dimensions of the filter element** AVANTE HEFA-50-50
W x H x D: 495 mm x 495 mm x 48 mm
- 1.2 Description of the test procedure** VDI 2052 Part 1 (September 1999)
- 1.3 Measured data/Results**
- (i) Fractional separation efficiency:
 $d_{50} = 2.9 \mu\text{m}$ at volume flow rate of 1152 m³/h
 $d_{50} = 1.8 \mu\text{m}$ at volume flow rate of 1440 m³/h
 - (ii) Increase of differential pressure during continuous loading process over 2 h at 59 mg/m³ / 1440 m³/h: 4 Pa
- 2. Validity of the test report**
This test certificate applies exclusively to the aerosol separators which are identical to the tested product.
- 3. General notice**
The present test certificate consists of 5 pages. It may not be published in extract form without the written permission of DMT GmbH & Co. KG.

DMT GmbH & Co. KG

Plant & Product Safety Building Safety – Refrigeration & Air Quality



Dirk Renschen
2023.08.31
15:34:56 +02'00'

Dr. Renschen



(Digitale Signatur)

Johannes
Schamberg
2023.09.01 07:35:06
+02'00'

Dipl.-Ing. Joh. Schamberg