

 بن غاطي BINGHATTI	Materials Submittal Form	 SILVER STONE ENGINEERING CONSULTANTS	 GRANADA EUROPE CONSTRUCTION
--	---	--	--

Project Name:	BINGHATTI PALM 01		
Project Proposed:	4B+G+10 FLOORS+ROOF	Client:	BINGHATTI Developers
Project Location:	PALM JUMEIRAH	Engineering Consultant:	Silverstone Eng'g Consultants
Project Plot No.:	PJTR18A&B 3812953	Main Contractor:	Granada Europe Const. Co.

MSF Reference No.:	PJ0001-GME-MAS-EL-FA-0006	MSF Date:	13 July 2026	MSF Rev.:	01
---------------------------	---------------------------	------------------	--------------	------------------	----

Engineering Consultant has fourteen (14) working days to respond after the document has been submitted.

MSF SCOPE OF WORK				
☐ ARCH	☐ STR	☒ MEP	☐ ID/ED	☐ AI

MSF SUBMITTALS INFORMATION:				
SPECS. Ref. No.	Description	Pages	Discipline	Remarks
	Materials Submittal for Cables for Fire Alarm and monitored emergency lighting systems	63 + cover	EL	M/s Al Arabia Manufacture: M/s Safeguard/Ramcro

MAIN CONTRACTOR CONFIRMATION					
☐ Project Engineer		☒ MEP Engineer		☒ Project Manager	
		Engr. Dinu Balakrishnan		Engr. Syed Saheed	
Signature:	Date:	Signature:	Date: 13 July 2026	Signature:	Date: 13 July 2026

The Contractor strictly confirms herewith that the MSF has been studied carefully & coordinated precisely as per the approval of all drawings from the authorities and approved specifications from the engineering consultant, enclosed with contractor comments (if required).

MSF ATTACHEMENT			
☐ Drawings	☐ Catalogues	☐ Samples	☒ Other: Data Sheet

QA/QC ENGINEERS COMMENTS AND ACKNOWLEDGMENT	
1. Please find the Supplier Compliance statement for REV-00 2. Final Approval Subject to SS Approval.	
☐ CIVIL	☒ MEP 

ENGINEERING CONSULTANT COMMENTS AND APPROVAL STATUS									
☐ Approved (A)			☒ Approved as Noted (B)				☐ Re- Submit (C)		
1. Final sizes approval subject to SPL and voltage drop calculations. 2. All glands and termination accessories must be fire rated and DCD approved. 3. Fireguard Global ISO 9001 certificate to be attached along with materials delivery. 4. Draft warranty letter minimum 12 months from the date of TOC to be attached along with materials delivery. 5. Sample section showing LPCB marking and batch traceability must be submitted for final approval 6. Final installation color coding must follow DCD requirements (white for emergency lighting, red for fire alarm loops). 7. List of lading and country of origin certificate to be attached along with materials delivery. 8. Delivery of materials must be with respect to the project program of work. 9. Subject to DCD approval.									
☐ ARCH			☐ STR		☒ MEP		☐		
Signature:	Date:	Signature:	Date:	Signature:	Date:	Signature:	Date:	Signature:	Date:

(B) Approved As Noted

Submittal was reviewed for design conformity and general conformance to contract documents only. The Contractor is responsible for confirming and correlating Dimension at job site for tolerance, clearance, quantities fabrication processes and techniques of construction, coordination of his works with other trades and full compliance with contract documents.

Reviewed By:  Malak Zaki
 Date: 13 July 2025
 SS Head of Supervision: Eng. Ahmad Odeh

