SAFETY COMMITTEE

Safety Committee Minutes

Minutes ref: SC-MIN-2026-09

Factory: Sample Apparel Ltd.

Meeting held on: 20/09/2026

Present: 9 committee members, including 5 worker representatives.

Item 3: The committee reviewed fire safety certificate FC-2025-0471 and the evacuation plan.

The electrical distribution boards were found labelled and covered; two loose cable trays were noted for repair.

Signed: Rahim Uddin (synthetic)

The inspection team visited all production floors, the cutting section, the finishing section and the store.

The electrical distribution boards were found labelled and covered; two loose cable trays were noted for repair.

Emergency lighting, exit signage and the fire alarm panel were tested in the presence of factory management.