


Heat Transfer Correlation 13.4



A fluid flows through a pipe with isothermal surface. Calculate the mean heat transfer coefficient $\bar{\alpha}$.

Reynolds number:

$$Re_d = \frac{u \cdot d}{\nu} = 1861.11$$

Thermal entry length:



$$L_{\rm th} = 0.05 \cdot {\rm Re_d} \cdot {\rm Pr} \cdot d = 155.87 \; {\rm m} > L$$

 $Nusselt\ number:$

$$\overline{\mathrm{Nu_{d}}} = \left(3.66 + \frac{0.0677 \cdot \left(\mathrm{Re_{d} \cdot Pr \cdot \frac{d}{L}}\right)^{1.33}}{1 + 0.1 \cdot \mathrm{Pr \cdot \left(\mathrm{Re_{d} \cdot \frac{d}{L}}\right)^{0.83}}}\right) \cdot \left(\frac{\eta}{\eta_{w}}\right)^{0.14} = 4.88$$

Heat transfer coefficient:

$$\bar{\alpha} = \frac{\overline{\mathrm{Nu_d}} \cdot \lambda_{\mathrm{f}}}{d} = 8.01 \ \mathrm{W/m^2K}$$