

Table 19.1: Emergency Evacuation Procedures

ITEMS

REQUIREMENTS

8. ASSEMBLY POINT OR ASSEMBLY AREA

1. GENERAL

- i. Each building shall have an "assembly point" in accordance with Table 19.1.8.
- ii. Assembly Point shall be predetermined, identified and designated with sign.
- iii. Large and distributed occupancies such as malls, theme parks, hospitals, schools shall have multiple assembly points.
- iv. Consideration shall be given to sheltered assembly points.

2. LOCATION

- i. The assembly point shall be minimum of 15 m away from the building it is serving.
- ii. Alternatively, an assembly point shall be at a distance, not less than the height of the building.
- iii. The assembly point shall be easily accessible.
- iv. The assembly point shall be in a location safe from the building structure, such that occupants are safe from fire heat radiation and falling debris.
- v. Assembly point shall be away from the fire access road and fire truck parking areas, such that the occupant assembly shall not hamper the fire fighters staging and operation activities.
- vi. The landscaping areas, parking lots, pedestrian ways, play grounds etc., away from the building shall be permitted as an assembly points.

3. SIZE

- i. The assembly point shall be large enough to accommodate the building occupants.
- ii. Where space is constraint, multiple assembly points in various areas shall be permitted.
- iii. A public large open space within 100 m of the building shall be permitted to be a "common assembly point" for a group of buildings owned by different owners.

4. SIGN BOARD

i. The assembly point shall be identified by the sign, in both Arabic and English, green colour and format, in accordance with **Figure 19.1**.



Figure 19.1.: Assembly Point Sign