

- 2.2.1.3.** Limit the fire to the space and deck of origin using appropriate on board fire extinguishers and fixed fire hydrants of marina.
- 2.2.1.4.** Marina operators shall have written fire strategy, emergency response plan, rules and regulations for regular inspections, maintenance and house keeping requirements of vessels, boats, yachts, dhows, marina and storage yards.
- 2.2.1.5.** Marina operators shall have equipment and methods to tow away the vessel on fire from rest of the moored vessels, to mitigate the spread of fire.
- 2.2.1.6.** Limit the fire to the space, area or deck of origin.
- 2.2.3.** The requirements in this chapter are the minimum guidelines. It is the responsibility of vessel designers, consultants, contractors, vessel owners and marina operators to refer to international standards and national regulations such as **UAE Yachts Regulations (for yachts above 24 m), NFPA 1, NFPA 301, NFPA 302, NFPA 303, NFPA 306, NFPA 307, NFPA 312 and ICC (Chapter 46)**, for further clarifications and code compliance.

