

Table 5.3: Application of Exit Signs and Directional Markings

LOCATION	REQUIREMENTS
15. STORAGE AND INDUSTRIAL OCCUPANCIES	<ul style="list-style-type: none"> i. Exit Signs and Directional Signs shall be provided as per Section 3. ii. High hazard areas (GROUP A-1 and GROUP A-2), Robotic storage and cold storage areas, industrial basements, Cable spread areas, shall be provided with Photoluminescent Exit Marking strips as per Table 5.1. 4. iii. Evacuation Plan shall be provided in each floor and at multiple locations as per Table 5.1.8.
16. MALLS	<ul style="list-style-type: none"> i. Exit Signs and Directional Signs shall be provided as per Section 3. ii. Tactile Signs, in compliance with Table 5.1.3. shall be installed at every exit iii. Play areas, Food courts and Cinema areas shall be provided with Photoluminescent Exit Marking strips as per Table 5.1. 4. iv. Evacuation Plan shall be provided in each floor and at multiple locations as per Table 5.1.8. v. Evacuation plans shall not be required at individual tenants.
17. PARKING	<ul style="list-style-type: none"> i. Exit Signs and Directional Signs shall be provided as per Section 3. ii. The vehicle exit route Signs shall be clearly distinguishable in size, in colour and in format from Exit Signs and Directional Signs as required by this chapter. iii. Robotic/Mechanical parking shall be provided with Photoluminescent Exit Marking strips on access walkways as per Table 5.1. 4. iv. Evacuation Plan shall be provided in each floor and at multiple locations as per Table 5.1.8.
18. PRIVATE VILLA	<ul style="list-style-type: none"> i. Exit Signs are not required, unless usage has changed and converted into another occupancy.
19. COMMERCIAL VILLA	<ul style="list-style-type: none"> i. Exit Signs are not required, unless usage has changed and converted into another occupancy.
20. FUEL DISPENSING STATION	<ul style="list-style-type: none"> i. Exit signs are not required, unless the buildings are other than facilities having only ground floor.

