



2.8. Extent of Fire Vehicle Access around the building

- 2.8.1. The accessway shall have a minimum width of 6 m throughout. Such accessway must be able to accommodate the entry and maneuvering of fire engine, extended ladders, pumping appliances, aerial appliances, turntable and / or hydraulic platforms.
- 2.8.2. Accessway shall be positioned so that the nearer edge shall be not less than 2 m or more than 10 m from the building, measured horizontally.

