

Table 3.4: Stair

ITEMS	REQUIREMENTS
20. STAIR TREAD, FLIGHTS AND ARRANGEMENT	<ul style="list-style-type: none"> ii. Exit stair designs shown in Figure 3.13.b. are not acceptable. (Refer to Figure 3.13.b.) <ul style="list-style-type: none"> a. Winders are not acceptable. b. Less than 3 steps at intermediate landings are not acceptable. c. Step riser height dimensions exceeding maximum variation of 10 mm within flight is not acceptable. d. Winders are not acceptable. e. Door in the middle of landing obstructing more than half of required landing width is not acceptable. f. Step riser height dimensions exceeding maximum variation of 10 mm within flight is not acceptable. g. Stair doors next to each other is not acceptable. h. Stair doors opening into each other and obstructing more than half of the required landing width is not acceptable. i. Stair doors next to each other is not acceptable j. Step riser height dimensions exceeding maximum variation of 10 mm within flight are not acceptable k. Stair doors next to each other is not acceptable l. Less than 3 steps not recommended but acceptable only from basement to ground floor or roof access from a floor below.