

6.1.15. Valves

- xxxvii. BS EN 593, Industrial valves. Metallic butterfly valves
- xxxviii. LPS 1040, Requirements and Testing Methods for Wet Alarm Valve Sets
- xxxix. LPS 1041, Requirements and Testing Procedures for the LPCB Approval and Listing of Dry Pipe Valve Sets
- xxxx. LPS 1185, Requirements for Testing Gear Operated Butterfly Valves
- xxxxi. LPS 1186, Requirements and Testing Methods for Check Valves
- xxxvii. EN 12259-2, Fixed firefighting systems. Components for sprinkler and water spray systems. Wet alarm valve assemblies
- xxxviii. EN 1074-1, Valves for fire water
- xxxiv. EN 1074-2, Valves for fire water
- xxxv. EN 12259-3, Fixed firefighting systems. Components for sprinkler and water spray systems. Dry alarm valve assemblies
- xxxvi. LPS TS3, Requirements and Testing for Deluge Valves and Actuators
- xxxvii. LPS 2071, Requirements for LPCB Approved Pre-Action Systems for use in sprinkler systems
- xxxviii. prEN 12259-9. Fixed firefighting systems. Components for sprinkler and water spray systems. Part 9. Deluge alarm valves
- xxxix. UL 789. Indicator Posts for Fire-Protection Service

6.1.16. Hangers

- i. ANSI/UL 203, Pipe Hanger Equipment for Fire Protection Service
- ii. FM 1951, 1952, 1953, Pipe Hanger Components for Automatic Sprinkler Systems
- iii. FM 1950, Seismic Sway Brace Components for Automatic Sprinkler Systems
- iv. LPS 1194, Requirements & Test Methods for Pipe Hangers

6.1.17. Fittings

- i. Fittings ANSI/UL 213, Rubber Gasketed Fittings for Fire Protection Service
- ii. FM 1920, Pipe Couplings and Fittings for Fire Protection Systems
- iii. UL 1474, Adjustable Drop Nipples for Sprinkler Systems
- iv. FM 1631, Adjustable and Fixed Sprinkler Fittings 1/2 Inch through 1 Inch Nominal Size
- v. ANSI/UL 2443, Flexible Sprinkler Hose with Fittings for Fire Protection Service
- vi. LPS 1219, Requirements and testing procedures for the LPCB approval and listing of pipe couplings
- vii. LPS 1261, Requirements for Testing Flexible Hoses for Sprinkler Systems

6.1.18. Water Motor Gong

- i. FM 1055, Approval Standard for Water Motor Gong.
- ii. BS EN 12259-4, Fixed firefighting systems. Components for sprinkler and water spray systems. Water motor alarms.
- iii. UL 346, Waterflow Indicators for Fire Protective Signaling Systems