

3. Application of Emergency Voice Evacuation System and Two-way Telephone Communication System

3.1. The application of Emergency Voice Evacuation or Communication System and Two-way Telephone Communication System shall be as per **Table 7.3.**

Table 7.3: Application of Emergency Voice Evacuation or Communication System

LOCATION	REQUIREMENTS
1. SUPER HIGHRISE BUILDINGS	i. Emergency Voice Evacuation or Communication System (EVC), in accordance with Section 2.4. , Shall be provided.
2. HIGHRISE BUILDINGS	ii. Tow-way Telephone System, in accordance with Section 2.5. , shall be provided.
3. MALLS	
4. ASSEMBLY OCCUPANCIES	
5. AMUSEMENT AND THEME PARKS	
6. EDUCATIONAL OCCUPANCIES	
7. HOTEL OCCUPANCIES	
8. DETENTION AND CORRECTIONAL OCCUPANCIES	
9. STORAGE AND INDUSTRIAL OCCUPANCIES HAVING BUILT-UP AREA MORE THAN 5000 m ²	