



Table 1.9: Fire Resistance Separation and other requirement of incidental accessory /Occupancies.

INCIDENTAL ACCESSORY ROOMS AND OCCUPANCIES	REQUIRED SEPARATION WITH AUTOMATIC FIXED FIRE PROTECTION SYSTEM	REQUIRED SEPARATION WITHOUT AUTOMATIC FIXED FIRE PROTECTION SYSTEM	OTHER CONSTRUCTION AND PROTECTION REQUIREMENTS (See Chapter 9 for Fire Protection requirements Chapter 10 for smoke control requirements)
34. OPEN PARKING	1 Hour	2 Hour	<ul style="list-style-type: none"> i. Each parking level shall have permanent wall openings open to the atmosphere, for an area of not less than 0.4 m² for each linear meter of its two opposite exterior perimeter. ii. Such openings shall be distributed over 40 per cent of the building perimeter surfaces, uniformly over each of at least two opposing side surfaces. iii. Interior wall lines and column lines shall be at least 20% open. iv. Any part of the carpark shall be within 30 m of the permanent natural ventilation opening on the perimeter surface. v. See Chapter 10. Section 3.5., for further open parking categorization for smoke management system purposes.



Figure 1.7: Open parking for illustration