

Table 5.3: Application of Exit Signs and Directional Markings

LOCATION	REQUIREMENTS
7. BUSINESS OCCUPANCIES	<ul style="list-style-type: none"> i. Exit Signs and Directional Signs shall be provided as per Section 3. ii. Evacuation Plan shall be provided in each floor and at multiple locations as per Table 5.1.8. iii. Evacuation plans shall not be required inside individual tenant spaces which are open plan offices and main exit is visible.
8. EDUCATIONAL	<ul style="list-style-type: none"> i. Exit Signs and Directional Signs shall be provided as per Section 3. ii. Nurseries shall be provided with Photoluminescent Exit Marking strips as per Table 5.1. 4. iii. Auditoriums shall be provided with Photoluminescent Exit Marking strips as per Table 5.1. 4. iv. Evacuation Plan shall be provided in each floor and at multiple locations as per Table 5.1.8.
9. HEALTHCARE OCCUPANCIES	<ul style="list-style-type: none"> i. Exit Signs and Directional Signs shall be provided as per Section 3. ii. Tactile Signs, in compliance with Table 5.1.3. shall be installed at every exit. iii. Patient rooms shall not be required to be provided with Exit Signs. iv. Evacuation Plan shall be provided in each floor and at multiple locations as per Table 5.1.8.
10. RESIDENTIAL OCCUPANCIES	<ul style="list-style-type: none"> i. Exit Signs and Directional Signs shall be provided at exit passageways and corridors as per Section 3. ii. Residential apartments and dwelling units shall not be required to be provided with exit signs. iii. Evacuation Plan shall be provided in each floor and at multiple locations as per Table 5.1.8.
11. HOTEL	<ul style="list-style-type: none"> i. Exit Signs and Directional Signs shall be provided as per Section 3. ii. Tactile Signs, in compliance with Table 5.1.3. shall be installed at every exit iii. All hotel occupancies shall be provided with Floor proximity Signs as per Table 5.1.7. iv. Guest rooms shall not be required to be provided with exit signs. v. Evacuation Plan shall be provided in each floor, in each guest room and at multiple locations as per Table 5.1.8.
12. DAY CARE OCCUPANCIES	<ul style="list-style-type: none"> i. Exit Signs and Directional Signs shall be provided as per Section 3. ii. Evacuation Plan shall be provided in each floor and at multiple locations as per Table 5.1.8.
13. DETENTION AND CORRECTIONAL OCCUPANCIES	<ul style="list-style-type: none"> i. Exit Signs shall not be required in dwelling cell areas. ii. General public areas, offices and areas accessible to general public shall be provided with Exit Signs and Directional Signs as per Section 3. iii. Tactile Signs, in compliance with Table 5.1.3. shall be installed at every exit iv. Evacuation Plan shall be provided in each floor and at multiple locations as per Table 5.1.8.
14. MERCANTILE OCCUPANCIES	<ul style="list-style-type: none"> i. Exit Signs and Directional Signs shall be provided as per Section 3. ii. Directional Signs as per Table 5.1.2. shall be provided for aisles and rack areas where exit is not directly visible. iii. Evacuation Plan shall be provided in each floor and at multiple locations as per Table 5.1.8.