



Table 1.14.a.: MCM and ACP On Non-Fire Resistance rated and Non-Load bearing Exterior wall coverings-Test Requirements

OCCUPANCY AND TYPE OF BUILDING	TEST 1 MCM/ ACP CORE AND PANEL AS PRODUCT	TEST 2 MCM/ ACP PANELS WITH WALL ASSEMBLY
1. SUPER HIGHRISE BUILDING 2. HIGHRISE BUILDING 3. MALLS 4. THEME PARKS 5. SCHOOLS 6. HOSPITALS 7. ASSEMBLY	i. Core shall be tested to the criteria iii and iv. ii. Panel shall be tested with the thickness intended to the criteria iii and iv. iii. EN 13501-1 With pass criteria A1 OR A2-s1-d0 AND iv. ASTM D1929 MCM/ACP shall have self ignition temperature of not less than 343°C.	v. BS 8414 –1 Or 2 With pass criteria as per BRE 135 OR vi. NFPA 285 With pass criteria “Pass” OR vii. FM 4881 With pass criteria “Pass” OR viii. ISO 13785-2 With pass criteria “Pass”
8. LOWRISE BUILDING 9. MIDRISE BUILDING 10. WAREHOUSE 11. INDUSTRIAL	i. Core shall be tested to the criteria iii and iv. ii. Panel shall be tested with the thickness intended to the criteria iii and iv. iii. EN 13501-1 With pass criteria B-s1-d0 AND iv. ASTM D1929 MCM/ACP shall have self ignition temperature of not less than 343°C.	v. BS 8414 –1 Or 2 With pass criteria as per BRE 135 OR vi. NFPA 285 With pass criteria “Pass” OR vii. FM 4881 With pass criteria “Pass” OR viii. ISO 13785-2 With pass criteria “Pass”