



**Table 1.11.b.: Compartmentation (Sub divisions) within the same occupancy**

OCCUPANCY	COMPARTMENTATION (SUB DIV SIONS) WITH SPRINKLER	COMPARTMENTATION (SUB DIV SIONS) WITHOUT SPRINKLER
18. PARKING STRUCTURES	<ul style="list-style-type: none"> <li>i. 2 Hour fire resistance rated walls from foundation to roof shall separate parking structures from other occupancies except repair shops, which shall be separated with 1 Hour fire resistance rated wall.</li> <li>ii. Such fire resistance rated wall shall not be required when parking structure is separated from other occupancies by 3 m.</li> <li>iii. Parking structures located above or below other occupancy, shall have construction type as of other occupancy but not less than Type I or Type II.</li> </ul>	<ul style="list-style-type: none"> <li>i. 2 Hour fire resistance rated walls from foundation to roof shall separate parking structures from other occupancies except repair shops, which shall be separated with 1 Hour fire resistance rated wall.</li> <li>ii. Such fire resistance rated wall shall not be required when parking structure is separated from other occupancies by 3 m.</li> <li>iii. Parking structures located above or below other occupancy, shall have construction type as of other occupancy but not less than Type I or Type II.</li> </ul>