6.1.6. Smoke Control Panel (SCP) and Power Supply (With 3 hour battery backup, enclosure rating of UL 864, IP 65 or above)

i. ANSI/UL 864, Standard for Control Units and Accessories for Fire Alarm Systems, category UUKL, for their intended purpose.
ii. ISO 21927-9:Smoke and heat control systems — Specification for control equipment.
iii. ISO 21927-10: Smoke and heat control systems — Specification for power output devices.
iv. EN 12101-10: Smoke and heat control systems. Power supplies.

6.1.7. Smoke Curtains or Draft Curtains (Rated at 600^0 C for 2 hours)

i. ISO 21927-1: Smoke and heat control systems, Specification for smoke barriers.
ii. EN 12101-1: Smoke and heat control systems. Specification for smoke barriers.

6.1.8. Fire Curtains (Rated at 1100^0 C for 2 hours)

i. UL 10D. Standard for Fire Curtains.
ii. BS 476; part 22, Fire Resistance Test to Building Material
iii. BS 8524-1:Active fire curtain barrier assemblies Part 1 - Specification
iii. BS EN 1634-1, Fire resistance and smoke control tests for door and shutter assemblies

6.1.9. Natural Smoke and Heat Vents (Rated at 300^0 for 30 minutes)

i. ISO 21927-2: Smoke and heat control systems — Specification for natural smoke and heat exhaust ventilators.
ii. FM 4430, Heat and Smoke Vents.
iii. UL 793, Standard for Automatically Operated Roof Vents for Smoke and Heat
iv. EN 12101-2: Smoke and heat control systems. Specification for natural smoke and heat exhaust ventilators.

6.1.10. Mechanical Extract Fans and Jet Fans (Rated at 400^0 for 2 hours)

i. EN-12101-3: Smoke and heat control systems. Specification for powered smoke and heat exhaust ventilators.
ii. UL 705, Standard for Power Ventilators.
iii. EN 13501-4: Fire classification of construction products and building elements - Part 4: Classification using data from fire resistance tests on components of smoke control systems.

6.1.11. Powered Smoke and Heat Exhaust Ventilators (Rated at 400^0 for 2 hours)

i. EN 12101-3: Smoke and heat control systems. Specification for powered smoke and heat exhaust ventilators.
ii EN ISO 13350: Industrial fans. Performance testing of jet fans.
iii. EN 13501-4: Fire classification of construction products and building elements - Part 4: Classification using data from fire resistance tests on components of smoke control systems
iv. UL 705, Standard for power ventilators