

Table 3.21.: Educational, Group B, C. (Schools and Colleges)

ITEMS	REQUIREMENTS
8. LABORATORY	<ul style="list-style-type: none"> i. Laboratory using flammable material shall be separated from the rest of the area with 1 hour fire resistance rated wall. ii. Flammable gas used for laboratory shall be designed and installed in accordance with Chapter 11. Liquid Petroleum Gas.
9. OTHER SAFETY PRECAUTIONS	<ul style="list-style-type: none"> i. Clothing and personal effects shall not be stored in corridors unless building is sprinklered. ii. Artwork, craftwork and teaching materials shall not exceed 20% in non sprinklered building and 50% in sprinklered building, of the wall area.
10. EXITS FROM OPEN PODIUM	<ul style="list-style-type: none"> i. Educational occupancies having open podiums for assembly purposes, shall ensure 2 exits remotely located as per Section 4.4. ii. Such required 2 exits shall be any of the following. <ul style="list-style-type: none"> a. Exits leading back into building, to the building exit stairs. b. Enclosed exit stairs to exterior discharge from the podium. c. Open or outside exterior stairs as per Table 3.4., 14., discharging directly outside to publicway. d. Combinations of above options a, b, and c.