

5.12. Mall, Group A. (Covered Mall)

5.12.1. The Mall, Group A, (Covered Mall) occupancies shall comply with **Table 3.33.** along with all other sections of this chapter. Where conflicts arise between this section and other sections of this Chapter or code, the requirements of this section shall prevail.

Table 3.33.: Mall, Group A, (Covered Mall)

ITEMS	REQUIREMENTS
1. MULTIPLE OCCUPANCY	i. The mall building shall be treated as a single building for the purpose of calculation of means of egress and shall be subject to the requirements for appropriate occupancies.
2. MALL PEDESTRIAN WAY	i. Mall pedestrian way shall be not less than 6100 mm wide in its narrowest dimension. ii. On each side of the mall floor area, the mall shall be provided with an unobstructed exit access of not less than 3050 mm in clear width parallel to, and adjacent to, the mall tenant front. iii. Exit access of 3050 mm is acceptable only where tenant spaces open to such exit access on only one side. Where exit access caters to tenant spaces on its both sides, the exit access shall not be less than 6100 mm. iv. Transoms, louvers, or transfer grilles shall be prohibited in walls or doors of exit access corridors.
3. EXITS	i. Minimum width of exit shall not be less than 1675 mm. ii. Every floor of a mall shall be provided with the number of means of egress as required by occupant load and capacity, with not less than two means of egress remotely located from each other available from any point in the mall. iii. Class A and Class B mercantile occupancies connected to a mall shall be provided with the number of means of egress as required by occupant load and capacity, with not less than two means of egress remotely located from one another. iv. Each individual anchor building shall have its 100 % means of egress independent of the mall. v. Each individual major tenant of a mall shall have a minimum of 50% of its required means of egress independent of the mall. vi. Each Assembly occupancy within mall having an occupant load of more than 500 shall have a minimum of 50% of its required means of egress independent of the mall.
4. CORRIDORS AND EXIT PASSAGEWAYS	i. Minimum width of exit access corridors and passageways shall not be less than that required for the occupant load it is serving but in no case, not less than 1675 mm. ii. Exit passageways in a mall building shall be permitted to accommodate the occupant loads independently from either occupant load assigned from only mall or largest occupant load assigned from a single tenant space.
5. KIOSKS	i. The minimum horizontal separation between kiosks or groups of kiosks shall not be less than 6 m. ii. The minimum pedestrian way and exit accessway available from any side of the kiosk shall not be less than 1.5 m. iii. Each kiosk, or group of kiosks, or similar structure shall have a maximum area of 18 m ² . iv. See Chapter 1, Table 1.9.48. and material approval requirement in Section 7.1.40.