



Table 1.9.: Fire Resistance Separation and other requirement of incidental accessory /Occupancies.

INCIDENTAL ACCESSORY ROOMS AND OCCUPANCIES	REQUIRED SEPARATION WITH AUTOMATIC FIXED FIRE PROTECTION SYSTEM	REQUIRED SEPARATION WITHOUT AUTOMATIC FIXED FIRE PROTECTION SYSTEM	OTHER CONSTRUCTION AND PROTECTION REQUIREMENTS (See Chapter 9 for Fire Protection requirements Chapter 10 for smoke control requirements)
65. ELECTRICAL ROOM	1 Hour	1 Hour	i. Separation and Compartmentation shall be complete with walls, floor and opening protection with approved fire stopping system. ii. Fire door shall be 60 minutes fire rated.
66. TELEPHONE ROOM	1 Hour	1 Hour	i. Separation and Compartmentation shall be complete with walls, floor and opening protection with approved fire stopping system. ii. Fire door shall be 60 minutes fire rated.
67. ETS ROOM	0 Hour	0 Hour	
68. GSM ROOM	0 Hour	0 Hour	