

4.6. Storage of Spare LPG Containers

- 4.6.1.** Spare storage of filled LPG Containers with capacity more than 45 kg is not allowed, unless it is in bulk storage yards, LPG distributing facilities or approved by Civil Defence upon risk assessment and evaluation.

4.7. Bulk LPG Plants, Dispensing Units, Storage and Distribution facilities

- 4.7.1.** Bulk LPG plants, Dispensing Units, Storage and Distribution facilities shall be evaluated with Fire and Safety risk assessment. Civil Defence approval shall be based on such risk assessment reports.

