



Table 1.15.a.: EIFS and ETICS on Non-Fire Resistance rated and Non-Load bearing Exterior wall coverings-Test Requirements

OCCUPANCY AND TYPE OF BUILDING	TEST 1 EIFS/ETICS COMPONENTS AND PANEL AS PRODUCT	TEST 2 EIFS/ETICS AS WALL ASSEMBLY
1. ANY BUILDING 2. ANY INSTALLATION 3. ANY AESTHETICS	i. All components of the EIFS (All layers including EPS/XPS, coating, insulation, mesh, adhesive and finish.) shall be class A (Flame spread 0-25, Smoke development 0-450) when individually tested to ASTM E 84 or UL 723 AND ii. NFPA 268 With pass criteria "No Ignition at 12.5 kw/m ² at 20 minutes"	iii. BS 8414 –1 Or 2 With pass criteria as per BRE 135 OR iv. NFPA 285 With pass criteria "Pass" OR v. FM 4881 With pass criteria "Pass" OR vi. ISO 13785-2 With pass criteria "Pass"