

5. Operational Requirements for Marina Management

- 5.1. Operational and management requirements for marinas shall comply with Table 20.3.

Table 20.3.: Operation and Management of Marinas

ITEMS	1REQUIREMENTS
1. MARINA MANAGEMENT AND OPERATOR'S RESPONSIBILITY	<p><u>1. GENERAL</u></p> <ul style="list-style-type: none"> i. While code compliant design of the marina can reduce certain hazards and risks, the fact remains that proper management of the facility is an important element for reducing the risk of fire at marinas. ii. The marina operators and management shall adopt procedures, prepare emergency action plan, inspection routines and maintenance verification procedures to demonstrate that the facility and equipment are complaint to this code. <p><u>2. PERMIT TO OWNERS</u></p> <ul style="list-style-type: none"> i. The marina management shall not allow any boats into their marinas to be berthed without issuing a permit to the owner. ii. Such a permit shall be issued only after verifying and receiving a copy of the following. <ul style="list-style-type: none"> a. Certification of Compliance of the boat to UAE yacht regulations. b. Valid license for the boat and the owner. c. Valid insurance for the boat and the owner. d. Valid annual safety inspection report for the boat, issued by authorized inspection and maintenance agency. e. Valid annual inspection report of the fire detection, extinguishers and protection systems of the boat, issued by Civil Defence approved inspection and maintenance agency. f. Undertaking from the owner to abide by the fire and safety regulations of the marina operator, such as but not limited to 'no live cooking on board', 'no Sheesha on board' and 'no barbeque on board' . g. Undertaking from the owner to abide by the speed limit of 3 nautical miles at the marinas, boatyards and terminals. iii. The marina operator shall visually inspect the boat to verify good condition of the boat prior to issuing the permit. <p><u>3. FIREBOATS AND TOWING BOATS</u></p> <ul style="list-style-type: none"> i. It is marina management responsibility to be self sufficient with a minimum of one fireboat fully equipped with the following. <ul style="list-style-type: none"> a. A fixed fire pump of not less than 1250 gpm, capable of delivering 6.9 bar pressure, necessary hose with nozzles. b. A fixed foam extinguisher, with minimum capacity of 150 Ltr., with necessary hose and nozzles. c. A fixed multipurpose dry powder extinguisher, with a minimum capacity of 50 kg, with necessary hose and nozzle. d. A fixed CO2 fire extinguisher, with a minimum of 20 kg capacity, with necessary hose and nozzle. ii. It is marina management responsibility to be self sufficient with a towboat having a minimum capacity required to tow away the biggest vessel that the management permits in their marina.