

A2. Drawing Submission Requirements

A2.2. General requirements

ANNEXURE 2

Table A2.1: DRAWING SUBMISSION-General Requirements	
ITEM	REQUIREMENTS
5. REASONS FOR REJECTION OF APPLICATIONS	 vi. Smoke control/ Management drawings submitted to Civil Defence will be rejected without review, comments or suggestions if any of the following is true. a. With HVAC drawings or details. b. Smoke control drawings superimposed on life safety details. c. Without legend d. Without ducting distribution. e. Without all floor plans f. Without arrow marks for supply and return indications. g. Without control panel locations. h. Without riser diagrams. i. Without typical details and specifications for fans, ducts and curtains, if any. vii. LPG/ Natural gas drawings submitted to Civil Defence will be rejected without review, comments or suggestions if any of the following is true.
	a. LPG drawings superimposed on life safety details. b. Without legend c. Without piping distribution. d. LPG piping crossing through stairs, lift lobbies, garbage rooms. e. Without tank locations, sizes, capacity and separation dimensions. f. Without fill line location. g. Without PRDP location. h. Without all floor plans i. Without typical tank installation details. j. Without gas detectors and control panel locations. k. Without riser diagrams.
6. LEGENDS ON THE DRAWINGS	 i. Drawings submitted to Civil Defence shall essentially have the symbols and legend as required below. a. LIFE SAFETY drawings shall have symbols and legend as per Figure A2.1.1. b. FIRE ALARM SYSTEM drawings shall have symbols and legend as per Figure A2.1.2. c. FIRE PROTECTION drawings shall have symbols and legend as per Figure A2.1.3. d. EMERGENCY LIGHTING drawings shall have symbols and legend as per Figure A2.1.4. e. SMOKE CONTROL drawings shall have symbols and legend as per Figure A2.1.5. f. LPG SYSTEM drawings shall have symbols and legend as per Figure A2.1.6.

