

Table 9.7.KK.: Sprinkler and In rack sprinkler Schemes and Layouts

SHAMES	REQUIREMENTS	SCHEMATIC
<b>12. LAYOUT L-9</b>	<p>i. The in-rack sprinkler configuration shall be as per the figure.</p> <p>ii. The in-rack sprinkler calculation shall be for 8 sprinklers, for one level of in-rack, 12 sprinklers, if two levels of in-rack and 18 sprinklers if more than two levels of in-rack.</p>	