

Table 10.7.: Theater Smoke Management System

ITEMS	REQUIREMENTS
8. STAND-BY FAN	i. Back-up (Stand-by) fans shall not be required for theater smoke management systems.
9. STAND-BY POWER	i. Theater smoke management system, Control panel, automatic Smoke curtains, Fan shall be provided with emergency power.

