



Table 1.17.c.: Sandwich Panel in various applications -Test Requirements

APPLICATIONS	TEST 1 SANDWICH PANEL AS PRODUCT	TEST 2 SANDWICH PANEL IN WALL ASSEMBLY
5. ROOFING-NON SPRINKLERED BUILDINGS (SHALL BE TESTED FOR THE THICKNESS INTENDED TO BE USED)	i. ASTM D1929 Shall have self ignition temperature of not less than 343°C.	ii. NFPA 276 With pass criteria "Class 1" OR iii. ASTM E 108 With pass criteria "Class A" OR iv. EN 13501-5 +A1 With pass criteria "Class Broof t4". OR v. UL 790 With pass criteria "Class A" OR vi. FM 4470 Or FM 4471 With pass criteria "Pass"