

Table 15.7.: Application of Accessible Features in a Building

ITEMS	REQUIREMENTS	EXCEPTIONS
2. ACCESSIBLE ENTRANCE AS PER TABLE 15.1. AND ICC ANSI 117.1	<p><u>1. PUBLIC ENTRANCES</u></p> <p>i. At least 60% of all public entrances shall be accessible.</p> <p><u>2. PARKING GARAGE ENTRANCE</u></p> <p>i. Where provided, direct access for pedestrians from parking structures to buildings or facility entrances shall be accessible</p> <p><u>3. ENTRANCE FROM TUNNEL/ ELEVATED WALKWAYS</u></p> <p>i. Where direct access is provided for pedestrians from a pedestrian tunnel or elevated walkway to a building or facility, at least one entrance to the building or facility from each tunnel or walkway shall be accessible.</p> <p><u>4. RESTRICTED ENTRANCES</u></p> <p>i. Where restricted entrances are provided to a building or facility, at least one restricted entrance to the building or facility shall be accessible.</p> <p><u>5. ENTRANCES FOR INMATES/ DETAINEES</u></p> <p>i. Where entrances used only by inmates or detainees and security personnel are provided at judicial facilities, detention facilities or correctional facilities, at least one such entrance shall be accessible.</p> <p><u>6. SERVICE ENTRANCE</u></p> <p>i. If a service entrance is the only entrance to a building or a tenant space in a facility, that entrance shall be accessible.</p> <p><u>7. ACCESSIBLE DWELLING UNITS/ TYPE A/ TYPE B</u></p> <p>i. At least one accessible entrance shall be provided to each tenant, dwelling unit and sleeping unit in a facility.</p>	<p>i. Loading and service entrances that are not the only entrance to a tenant space need not be accessible.</p>