



Table 1.9.: Fire Resistance Separation and other requirement of incidental accessory /Occupancies.

INCIDENTAL ACCESSORY ROOMS AND OCCUPANCIES	REQUIRED SEPARATION WITH AUTOMATIC FIXED FIRE PROTECTION SYSTEM	REQUIRED SEPARATION WITHOUT AUTOMATIC FIXED FIRE PROTECTION SYSTEM	OTHER CONSTRUCTION AND PROTECTION REQUIREMENTS (See Chapter 9 for Fire Protection requirements Chapter 10 for smoke control requirements)
			<ul style="list-style-type: none"> iii. Door shall be 90 minutes Fire resistance rated with motorized louvers, where the room doesn't open to exterior of the building. iv. Where located below grade, shall be on the perimeter of the space such that supply and exhaust can be achieved to exterior directly . v. Where located below grade, shall be separated from rest of the area by the required fire rating and motorized louvers or fire curtains shall be provided to achieve the required fire rating.
18. RMU (RING MAIN UNIT) ROOM	2 Hour	2 Hour	<ul style="list-style-type: none"> i. RMU Room shall be located above grade level, on the exterior perimeter of the building. ii. When located on the perimeter of the building, the separation shall be between RMU room and other occupancies. Front side of the room exposed to exterior need not be fire rated. iii. RMU Rooms protected with Automatic Clean agent systems should have motorized louvers. iv. Door shall be 90 minutes Fire resistance rated where the room doesn't open to exterior of the building.
19. MDF (MAIN DISTRIBUTION FRAME) ROOM AND MMR ROOM (MEET ME ROOM)	1 Hour	2 Hour	<ul style="list-style-type: none"> i. MDF Room shall be protected in accordance with Chapter 9, Table 9.30. ii. Door shall be 90 minutes Fire resistance rated where the room doesn't open to exterior of the building.
20. BOILER ROOM	1 Hour	2 Hour	<ul style="list-style-type: none"> i. Separation and Compartmentation shall be complete with walls, floor and opening protection. ii. Fire door shall be 60 minutes fire rated.
21. A/C PLANT ROOM	1 Hour	1 Hour	<ul style="list-style-type: none"> i. Separation and Compartmentation shall be complete with walls, floor and opening protection. ii. Fire door shall be 60 minutes fire rated.
22. BULK LAUNDRY ROOM	1 Hour	2 Hour	<ul style="list-style-type: none"> i. Separation and Compartmentation shall be complete with walls, floor and opening protection. ii. Fire door shall be 60 minutes fire rated.