

**Table 15.7.: Application of Accessible Features in a Building**

ITEMS	REQUIREMENTS	EXCEPTIONS
<b>5. ASSEMBLY AREA SEATING</b>  <b>AS PER TABLE 15.5. AND ICC ANSI 117.1</b>	<b>1. ASSEMBLY AREA WITH FIXED SEATING</b>  i. Wheelchair spaces and companion seats shall be as per <b>Table 15.5.</b> ii. In multilevel assembly seating areas, wheelchair spaces shall be provided on the main floor level and on one of each two additional floor or mezzanine levels. iii. Wheelchair spaces shall be provided in each luxury box, club box and suite within assembly facilities. iv. At least 5%, but not less than one, of the total number of aisle seats provided shall be designated aisle seats and shall be the aisle seats located closest to accessible routes. v. Lawn seating areas and exterior overflow seating areas, where fixed seats are not provided, shall connect to an accessible route. vi. Each assembly area where audible communications are integral to the use of the space shall have an assistive listening system. vii. Where stadiums, arenas and grandstands provide audible public announcements, they shall also provide equivalent text or visual information regarding events and facilities.	i. In multilevel assembly spaces utilized for worship services where the second floor or mezzanine level contains 25% or less of the total seating capacity, wheelchair spaces shall be permitted to all be located on the main level. ii. In multilevel assembly seating where the second floor or mezzanine level provides 25% or less of the total seating capacity and 300 or fewer seats, all wheelchair spaces shall be permitted to be located on the main level. iii. Wheelchair spaces in team or player seating serving areas of sport activity are not required to be dispersed.
	<b>2. DINING AREA</b>  i. In dining areas, the total floor area allotted for seating and tables shall be accessible. ii. Where dining surfaces for the consumption of food or drink are provided, at least 5%, but not less than one, of the dining surfaces for the seating and standing spaces shall be accessible and be distributed throughout the facility and located on a level accessed by an accessible route.	i. In buildings or facilities not required to provide an accessible route between levels, an accessible route to a mezzanine seating area is not required, provided that the mezzanine contains less than 25% of the total area and the same services are provided in the accessible area.
<b>6. TOILETS AND BATHING</b>  <b>AS PER TABLE 15.6. AND ICC ANSI 117.1</b>	i. Accessible toilets and bathrooms shall be as per <b>Table 15.6.</b> ii. Family or assisted-use bathing rooms shall include only one shower or bathtub fixture. Family or assisted-use bathing rooms shall also include one water closet and one lavatory. Where storage facilities are provided for separate-sex bathing rooms, accessible storage facilities shall be provided for family or assisted-use bathing rooms. iii. Family or assisted-use toilet and bathing rooms shall be located on an accessible route. iv. The accessible route from any separate-sex toilet room to a family or assisted-use toilet room shall not exceed 152 m. v. In passenger transportation facilities and airports, the <i>accessible route</i> from separate-sex toilet rooms to a family or assisted-use toilet room shall not pass through security checkpoints. vi. Where doors swing into a family or assisted-use toilet or bathing room, a clear floor space not less than 762 mm by 1219 mm shall be provided, within the room, beyond the area of the door swing	