## 6.1.27. Heavy Duty Mobile Equipment Protection Systems

i. FM 5970 - Heavy Duty Mobile Equipment Protection Systems.

#### **6.1.28. Fire Water Tanks and Ancillaries**

i. LPS 1276, Requirements for the LPCB Certification and Listing of above ground Suction Tanks for Sprinkler Systems.

#### 6.1.29. Fire rated Cable, Certified for 120 minutes

- EN 50200, Method of test for resistance to fire of unprotected small cables for use in emergency circuits
- UL 2196, Standard for Fire Test for Circuit Integrity of Fire-Resistive Power, Instrumentation, Control, and Data Cables
- iii. BS 8434-2, Methods of test for assessment of the fire integrity of electric cables. Test for unprotected small cables for use in emergency circuits. BS EN 50200 with a 930° flame and with water spray.
- iv. BS 7629-1, Electric cables. Specification for 300/500 V fire resistant screened cables having low emission of smoke and corrosive gases when affected by fire. Multicore and multipair cables.
- v. BS 6387, Test method for resistance to fire of cables required to maintain circuit integrity under fire conditions.
- vi. IEC 60331-1, Tests for electric cables under fire conditions.
- vii. IEC 60331-2, Tests for electric cables under fire conditions.
- viii. IEC 60332-2-2, Tests on electric and optical fibre cables under fire conditions.
- ix. IEC 60332-3-10, Tests on electric and optical fibre cables under fire conditions.
- x. IEC 60331-2, Tests for electric cables under fire conditions.
- xi. UL 1724, Outline of Investigation for Fire Tests for Electrical Circuit Protective Systems.
- xii. UL 1685, Standard for Vertical-Tray Fire-Propagation and Smoke-Release Test for Electrical and Optical-Fiber Cables.
- xiii. UL 1666, UL 1666 Test for Flame Propagation Height of Electrical and Optical-Fiber Cables Installed Vertically in Shafts.

# 6.1.30. Breeching inlet

i. UL 405, Fire Department connections.

### 6.1.31. Fire Pump Assembly

UL 448 D, Outline of Investigation for Fire Pump, Driver and Controller Assembly Rating Compatibility

