

Table 7.2: Specifications of Two-way Communication Systems

ITEMS	REQUIREMENTS
4. CIRCUITS AND WIRING	i. All circuits and wiring necessary for the operation of two-way telephone communication systems shall be 2 hour fire rated.
5. INSTALLATION	i. Wall-mounted telephone appliances or related jacks shall be not less than 910 mm and not more than 1680 mm above floor level with clear access to the appliance that is at least 760 mm wide. ii. If accessible to the general public, one telephone appliance per location shall be not more than 1220 mm above floor level.



**TWO-WAY TELEPHONE JACK FOR FIRE FIGHTERS
FOR ILLUSTRATION**