Table 3.4: Stair	
ITEMS	REQUIREMENTS
19. EQUIPMENT ACCESS	<ul> <li>i. Industrial Equipment Access shall comply to the following.</li> <li>a. Minimum Horizontal dimension of walkway, landing or platform shall be 560 mm.</li> <li>b. Minimum stair or ramp width shall be 560 mm.</li> <li>c. Minimum tread width shall be 560 mm.</li> <li>d. Minimum tread depth shall be 255 mm.</li> <li>e. Maximum riser height shall be 230 mm</li> <li>f. Maximum height between landings shall be 3660 mm.</li> <li>g. Minimum head room shall be 2030 mm.</li> <li>h. Minimum width of door opening shall be 560 mm.</li> <li>i. Railings height shall be 865 mm to 965 mm and shall be permitted to terminate directly above top and bottom risers.</li> </ul>
20. STAIR TREAD, FLIGHTS AND ARRANGEMENT	<ul> <li>i. Exit stair designs is preferred to be as per Figure 3.13.a. (Refer to Figure 3.13.a.)</li> <li>a. Regular flights and consistent dimensions of steps is acceptable.</li> <li>b. Consistent flights and consistent dimensions on all sides are acceptable.</li> <li>c. Consistent flights and consistent dimensions of steps are acceptable.</li> <li>d. Direct exit at discharge level from under the stair flight.</li> <li>e. Two doors on opposite sides are acceptable if each door swing does not obstruct more than half of the required landing width.</li> <li>f. RCC Stairs with separate core but common RCC divider is acceptable only in lowrise and midrise buildings provided whole stair complies with building construction type and separation distance.</li> <li>g. Straight run stairs are acceptable, provided maximum height between landings is 3660 mm.</li> <li>h. RCC Stairs with separate core but common RCC divider is acceptable only in lowrise and midrise buildings provided whole stair complies with building construction type and separation distance between exits.</li> <li>i. Consistent flights with consistent dimensions of steps on opposite sides are acceptable.</li> <li>j. RCC Stairs with separate core but common RCC divider is acceptable only in lowrise and midrise buildings provided whole stair complies with building construction type and separation distance between exits.</li> </ul>