MINISTRY OF INTERIOR	And Automatical State Control of the				
GEN. COMMAND OF CIVIL DEFENSE					
Table 9.10: Automatic Deluge Water Spray System					
ITEMS	REQUIREMENTS				
7. PIPING SUPPORT	 i. The system piping shall be supported to maintain its integrity under fire conditions. ii. The piping shall be supported from steel or concrete structural members or pipe stands. iii. Pipe stands used to support piping shall be in accordance with Table 9.10.B to determine maximum heights for pipe stands supporting various diameters of looped piping. iv. The distance between stands shall be as per Table 9.10.C. v. Pipe stands shall be constructed of Schedule 40 threaded pipe, malleable iron flange base, and shall have a threaded cap top. vi. Pipe stands shall be anchored to a concrete pier or footing with either drop-in anchors, quick bolts, or cast-in-place J hooks. vii. The piping shall be attached to the pipe stand with U-bolts or equivalent attachment. 				

chors, quick boits, or cast-in-place I hooks.
vii. The piping shall be attached to the pipe stand with U-bolts or equivalent attachment.
viii.The piping shall be supported and braced to restrict movement due to nozzle reac-
tion and water surges so that system performance and integrity is maintained.
ix. Hangers shall comply with Table 9.7.30.

Table 9.10.B.: Maximum Pipe stand Heights						
DIAMETER OF PIPE	PIPE STAND DIAMETER 40 mm	PIPE STAND DIAMETER 50 mm	PIPE STAND DI- AMETER 65 mm	PIPE STAND DIAMETER 80 mm	PIPE STAND DI- AMETER 100 mm	
1. 40 mm	3048 mm	4267 mm	5486 mm	8534 mm	9144 mm	
2. 50 mm	2438 mm	3658 mm	4876 mm	7925 mm	9144 mm	
3. 65 mm	1829 mm	3048 mm	4267 mm	7315 mm	9144 mm	
4. 80 mm		2438 mm	3658 mm	6705 mm	9144 mm	
5. 100 mm					3048 mm	

Table 9.10.C.: Pipe Stand Distance

LOOP SIZE	DISTANCE BETWEEN PIPE STANDS
1. 25 mm	3048 mm
2. 40 mm	3658 mm
3. 50 mm	4267 mm
4. 65 mm	4572 mm



