

4.8. Parking Requirements for Bulk delivery Trucks

- 4.8.1.** A clear, dedicated, safe LPG Propane tanker parking area for each bulk installation shall be provided close to the delivery point.
- 4.8.2.** The dedicated, safe tanker parking area for the LPG/ Propane tankers shall be identified during the facility planning stage.
- 4.8.3.** A detailed drawing indicating safe, dedicated tanker parking area to be prepared in the project planning stage and approval to be obtained from Civil Defence.
- 4.8.4.** For cumulative tank capacity up to 15000 liters (3,300 Gal.) minimum 14 meters in length, 4 meters clear wide, safe, dedicated parking space shall be provided with required approach maneuverability and turning radius for the tanker.
- 4.8.5.** For commutative tank capacity above 15000 liters (3,300 Gal.) minimum 20 meters in length, 4 meters clear wide, safe, dedicated parking space shall be provided with required approach maneuverability and turning radius for the tanker.
- 4.8.6.** The tanker parking area provided in the facility shall be so organized to ensure that the tankers can be moved out of the facility swiftly during any emergency in the same.
- 4.8.7.** No LPG installation without dedicated, safe clear parking for the delivery tankers shall be permitted.
- 4.8.8.** No LPG/propane bulk installations permitted with general public parking facility unless the same is completely cordoned with suitable valid approvals from Municipality, Police authorities. If such parking spaces are proposed, the detailed approvals from the Police authorities and Municipality to be produced during the project planning stage for concurrence to Civil Defence.
- 4.8.9.** No LPG/Propane installation shall be permitted where in the product delivery operation needs to be done from public roads or crowded public areas.
- 4.8.10.** Tanker parking area and delivery point shall not be permitted close to areas where open flames or other ignition sources like open restaurants, Shesha stalls etc. exist.
- 4.8.11.** No combustible materials, other fuel storage or fuel handling operations shall be permitted within 5 m from the dedicated tanker parking area and the delivery point.
- 4.8.12.** Tanker parking area / delivery points to be provided considering the future developments of adjacent facilities etc. made for safe bulk tanker unloading.