



## 2.13. Minimum Fire resistance ratings for Exit corridors based on Occupancies

**2.13.1.** Fire rating of Exit Corridors, Exit access corridors and internal partitions for various occupancies shall be as per **Table 1.11.a.**,

**Table 1.11.a.: Fire Resistance rating of Exit Corridors and Exit Access Corridors**

OCCUPANCY	EXIT ACCE CORRIDOR WITH SPRINKLER	EXIT ACCESS CORRIDOR WITHOUT SPRINKLER
1. ASSEMBLY	0 Hour	1 Hour
2. BUSINESS	0 Hour	1 Hour
3. EDUCATIONAL	0 Hour	1 Hour
4. HEALTHCARE GROUP A	0 Hour	1 Hour
5. HEALTHCARE GROUP B, C	0 Hour	1 Hour
6. RESIDENTIAL GROUP A, C	1 Hour	1 Hour
7. RESIDENTIAL GROUP B	1 Hour	1 Hour
8. PRIVATE VILLAS	Not Required	Not Required
9. HOTEL	1 Hour	1 Hour
10. DAY CARE	0 Hour	1 Hour
11. DETENTION CORRECTION	1 Hour	1 Hour
12. MERCANTILE	0 Hour	1 Hour
13. STORAGE GROUP A	1 Hour	1 Hour
14. STORAGE GROUP B, C	0 Hour	1 Hour
15. INDUSTRIAL GROUP A	1 Hour	1 Hour
16. INDUSTRIAL GROUP B, C	0 Hour	1 Hour