

### 5.13. Mall, Group B. (Open Mall )

**5.13.1.** The Mall, Group B, (Open Mall) occupancies shall comply with **Table 3.34.** along with all other sections of this chapter. Where conflicts arise between this section and other sections of this Chapter or code, the requirements of this section shall prevail.

**Table 3.34.: Mall, Group B, (Open Mall)**

ITEMS	REQUIREMENTS
<b>1. MULTIPLE OCCUPANCY</b>	i. The open mall building shall be treated as a single building for the purpose of calculation of means of egress and shall be subject to the requirements for appropriate occupancies.
<b>2. OPEN MALL PEDESTRIAN WAY</b>	i. Mall pedestrian way shall be unroofed serving multiple tenants, roofed or unroofed in ground only or not more than 3 levels. ii. Mall pedestrian way shall not be less than 3 m wide in its narrowest dimension. iii. On each side of the mall floor area, the mall shall be provided with an unobstructed exit access of not less than 3 m in clear width parallel to, and adjacent to, the open mall tenant front.
<b>3. EXITS</b>	i. Minimum width of exit shall not be less than 1675 mm. ii. Dead end shall be zero. iii. Commonpath shall be zero. iv. Every level of a open mall shall be provided with the number of means of egress as required by occupant load and capacity, with not less than two means of egress remotely located from each other available from any point in the open mall. v. Circulation at above grade shall be permitted to include exterior balconies, exterior corridors, exterior open stairs leading to exit discharging at exterior grade, outside the open mall.
<b>4. CORRIDORS AND EXIT PASSAGEWAYS</b>	i. Minimum width of exit access corridors and passageways, service corridors shall not be less than that required for the occupant load it is serving but in no case, not less than 1200 mm. ii. Exit passageways in a mall building shall be permitted to accommodate the occupant loads independently from the largest occupant load assigned from any single tenant space.
<b>5. KIOSKS</b>	i. The minimum horizontal separation between kiosks or groups of kiosks, and other structures within the mall shall be 3 m. ii. Each kiosk, or group of kiosks, or similar structure shall have a maximum area of 28 m <sup>2</sup> . iii. See <b>Chapter 1, Table 1.9.48.</b> and material approval requirement in <b>Section 7.1.39.</b>