

**Table 3.13.: Occupant Load Factors and Exit Capacity Factors**

OCCUPANCY	OCCUPANT LOAD FACTOR PER PERSON	STAIR CAPACITY PER PERSON	RAMP CAPACITY PER PERSON
<b>4. HEALTHCARE GROUP A,B</b>			
i. Inpatient treatment departments	22.3 m <sup>2</sup>	7.6 mm	5 mm
ii. Sleeping departments	11.1 m <sup>2</sup>	7.6 mm	5 mm
iii. Consultation departments	9.3 m <sup>2</sup>	7.6 mm	5 mm
iv. Clinics	9.3 m <sup>2</sup>	7.6 mm	5 mm
v. Limited Care	9.3 m <sup>2</sup>	7.6 mm	5 mm
vi. Both sides of Smoke Compartment	2.8 m <sup>2</sup> , net	7.6 mm	5 mm
<b>5. HEALTHCARE GROUP C</b>			
i. Ambulatory Health care	13 m <sup>2</sup>	7.6 mm	5 mm
<b>6. RESIDENTIAL GROUP A</b>			
i. Apartments	18.6 m <sup>2</sup>	7.6 mm	5 mm
<b>7. RESIDENTIAL GROUP B, C</b>			
i. Staff Accommodation, Hostels	18.6 m <sup>2</sup>	7.6 mm	5 mm
i. Labor Accommodation	18.6 m <sup>2</sup>	7.6 mm	5 mm
<b>8. PRIVATE VILLA</b>	None	None	None
<b>9. COMMERCIAL VILLA</b>	None	None	None
<b>10. DETENTION , GROUP A,B,C.</b>	11.1 m <sup>2</sup>	7.6 mm	5 mm
<b>11. HOTEL</b>			
i. Hotel Apartments	18.6 m <sup>2</sup>	7.6 mm	5 mm
i. Hotel Guest rooms	18.6 m <sup>2</sup>	7.6 mm	5 mm
<b>12. DAY CARE, GROUP A,B</b>	3.3 m <sup>2</sup> , net	10 mm	5 mm
<b>13. MERCANTILE, GROUP A,B,C.</b>			
i. Sales area on floor below street floor	2.8 m <sup>2</sup>	7.6 mm	5 mm
ii. Sales area on street floor	2.8 m <sup>2</sup>	7.6 mm	5 mm
iii. Sales area on floors above street floor	5.6 m <sup>2</sup>	7.6 mm	5 mm
iv. Sales area on two or more street floors	3.7 m <sup>2</sup>	7.6 mm	5 mm
v. Floors used only for offices	9.3 m <sup>2</sup>	7.6 mm	5 mm
vi. Floors used for goods and not public	27.9 m <sup>2</sup>	7.6 mm	5 mm