

Table 8.14: Auxiliary Rooms and Spaces Fire Detection and Alarm System

BUILDING / OCCUPANCY	APPLICABLE FIRE DETECTION AND ALARM SYSTEMS
24. PUMP ROOM	i. Heat Detector shall be provided as per Section 4.7.
25. GARBAGE ROOM	i. Heat Detector shall be provided as per Section 4.7.
26. BEDROOM	i. Sounder based Smoke Detector shall be provided as per Section 4.3.
27. LIVING ROOM	i. Smoke Detector shall be provided as per Section 4.3.
28. OPEN KITCHEN	<p>i. Detectors specifically listed for Kitchen shall be provided as per their listing specifications.</p> <p>OR</p> <p>i. Heat Detector in the kitchen shall be provided as per Section 4.7. along with Smoke Detector, 3 m away from the Kitchen counter, in the living room shall be provided as per Section 4.3.</p> <p>OR</p> <p>i. Multisensors specifically listed for Kitchen shall be provided as per Table 8.12.1.</p>
29. CLOSED KITCHEN	<p>i. Detectors specifically listed for Kitchen shall be provided as per their listing specifications.</p> <p>OR</p> <p>i. Heat Detector in the kitchen shall be provided as per Section 4.7.</p>
30. CORRIDOR	i. Smoke Detector shall be provided as per Section 4.3.
31. TEMPORARY KIOSKS	i. Battery Operated Smoke Detectors, listed and approved by Civil Defence shall be provided.
32. TEMPORARY TENTS	i. Battery Operated Smoke Detectors, listed and approved by Civil Defence shall be provided.
33. TEMPORARY MODULAR HOUSES/ OFFICES	i. Smoke Detector shall be provided as per Section 4.3.
34. FOOD TRUCKS	i. Heat Detector shall be provided as per Section 4.7.
35. MERCANTILE TRUCKS	i. Heat Detector shall be provided as per Section 4.7.
36. BUILDING ROOFS	i. Building roofs used for restaurant seating, assembly and as Sheesha bars shall be provided with Manual Fire Detection and Alarm System, as per Section 4.10.
37. OPEN STORAGE SHEDS	i. Manual Fire Detection and Alarm System, as per Section 4.10.