

**Table 13.1: General Requirements for Flammable and Combustible Liquid Storage**

ITEM	REQUIREMENTS
<b>15. OTHER REQUIREMENTS</b>	<ul style="list-style-type: none"> <li>i. Other requirements for flammable and combustible liquids such as but not limited to, Emergency venting of Above ground liquid storage tanks, Processes facilities and specific operations facilities using flammable and combustible liquids, Explosion protection, Emission mitigation etc. shall be as per <b>NFPA 30, NFPA 30A, IFC, API</b> and relevant international codes and standards.</li> <li>ii. Fire Detection and Alarm System shall be provided for all the enclosed spaces and shall be in accordance with <b>Chapter 8. Fire Detection and Alarm System.</b></li> <li>iii. All facilities storing aboveground flammable and combustible liquids, either indoor or outdoor, shall be provided with Automatic Fire Protection systems. Selection and design criteria of such Fire Protection System shall be in accordance with relevant tables of <b>Chapter 9. Fire Protection Systems.</b></li> <li>iv. All facilities storing flammable and combustible liquids shall have required means of egress, travel distances, dead ends and commonpath in accordance with High Hazard occupancy requirements and shall comply with <b>Chapter 3. Means of Egress.</b></li> <li>v. Fire extinguishers shall be provided throughout facilities storing flammable and combustible liquids in accordance with <b>Chapter 4. Fire Extinguishers.</b></li> <li>vi. Adequate Hazard identification signs, Electrical Classification signs, signs for Health effects of hazardous materials shall be provided at all facilities storing, handling and dispensing flammable and combustible liquids. Exit Signs shall be provided in accordance with <b>Chapter 5. Exit Signs.</b></li> <li>vii. Emergency Lighting shall be provided for facilities storing flammable and combustible liquids and shall comply with <b>Chapter 6. Emergency Lighting.</b></li> </ul>