

**Table 15.1.: Accessible Routes Requirement**

ITEMS	REQUIREMENTS
<b>4. CLEAR WIDTH</b>	<ul style="list-style-type: none"> <li>i. Clear width of an accessible route shall be 915 mm.</li> <li>ii. Where an accessible route makes a 180 degree turn around an object that is less than 48 inches (1220 mm) in width, clear widths shall be 1065 mm minimum approaching the turn, 1220 mm minimum during the turn, and 1065 mm minimum leaving the turn.</li> <li>iii. An accessible route with a clear width less than 1525 mm shall provide passing spaces at intervals of 61 m maximum. Passing spaces shall be either a 1525 mm minimum by 1525 mm minimum space, or an intersection of two walking surfaces that provide a T-shaped turning space, provided the base and arms of the T-shaped space extend 1220 mm minimum beyond the intersection.</li> </ul>
<b>5. DOORS</b>	<ul style="list-style-type: none"> <li>i. Minimum clear width of the doorway or at least one of the active leaves of doorways with two leaves shall be 915 mm as per <a href="#">Chapter 3. Means of Egress</a>.</li> <li>ii. Door closers and door stops shall be permitted to be 1980 mm minimum above the floor.</li> <li>iii. Minimum maneuvering clearances at manual swinging doors shall comply with <a href="#">Table 15.1.a.</a> and shall include the full clear opening width of the doorway.</li> <li>iv. Minimum maneuvering clearances at sliding and folding doors shall comply with <a href="#">Table 15.1.b.</a></li> </ul>

**Table 15.1.a.: Maneuvering clearance distances at Manual Doors**

APPROACH DIRECTION	DOOR SIDE	PERPENDICULAR TO DOORWAY	PARELLEL TO DOORWAY
<b>1. FROM FRONT</b>	Pull Side	1525 mm	455 mm
<b>2. FROM FRONT</b>	Push Side	1220 mm	0 mm
<b>3. FROM HINGE SIDE</b>	Pull Side	1525 mm	915 mm
<b>4. FROM HINGE SIDE</b>	Pull Side	1370 mm	1065 mm
<b>5. FROM HINGE SIDE</b>	Push Side	1065 mm	560 mm
<b>6. FROM LATCH SIDE</b>	Pull Side	1220 mm	610 mm
<b>7. FROM LATCH SIDE</b>	Push Side	1065 mm	610 mm

**Table 15.1.b.: Maneuvering clearance distances at Sliding and Folding Doors**

APPROACH DIRECTION	PERPENDICULAR TO DOORWAY	PARELLEL TO DOORWAY
<b>1. FROM FRONT</b>	1220 mm	0 mm
<b>2. FROM NON LATCH SIDE</b>	1065 mm	560 mm
<b>3. FROM LATCH SIDE</b>	1065 mm	610 mm

## Did You Know?

UAE customs exempts goods and materials used by people with disabilities from custom duties.